

STATE OF COLORADO

John W. Hickenlooper, Governor
Christopher E. Urbina, MD, MPH
Executive Director and Chief Medical Officer

Dedicated to protecting and improving the health and environment of the people of Colorado

4300 Cherry Creek Dr. S. Laboratory Services Division
Denver, Colorado 80246-1530 8100 Lowry Blvd.
Phone (303) 692-2000 Denver, Colorado 80230-6928
Located in Glendale, Colorado (303) 692-3090

<http://www.cdph.state.co.us>



Colorado Department
of Public Health
and Environment

MAR 17 2011

Mr. Jim Cain, RSO
Cotter Cañon City Milling Facility
P.O. Box 1750
Cañon City, CO 81215-1750

Subject: Review of Demolition Plan Appendix – Boiler House

Docket # 9602

Mr. Cain,

Radiation Management Unit staff has reviewed the subject document as re-submitted on February 14, 2011. It is acceptable to the Department with the following additions:

1. Add a task in the plan for the asbestos survey called out in Appendix A and discuss abatement process if necessary. The Master Plan calls for review of a previous survey conducted in 2001 that identified asbestos as being in the building.
2. The contractor plan cited in Section 4.2.6 shall be provided to the Department prior to mobilization by the contractor.

If you have any additional comments, please contact Phil Egidi at (970) 248-7162 or electronically at phil.egidi@state.co.us or myself at 303-692-3423 or at steve.tarlton@state.co.us.

Sincerely,

Steve Tarlton, Manager
Radiation Program

SFT:pve

Cc:
Edgar Ethington
John Hamrick
File 369-01 f3.