Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
Nov 24th – Dec 31st

11/24/14: Regular checks and readings.

11/26/14: Regular checks and readings.

11/28/14: Regular checks and readings.

12/1/14: Regular checks and readings. Collected and delivered monthly samples.

12/3/14: Regular checks and readings. Pulled membrane from RO to confirm model number.

12/5/14: Regular checks and readings. Checked the generators fuel and oil levels. Installed new light switch at Boxelder Pump house.

12/6/14: (Saturday) – onsite at 31501 E 167th Ave due to a water leak.

12/8/14: Regular checks and readings.

12/10/14: Regular checks and readings.

12/12/14: Regular checks and readings.

12/15/14: Regular checks and readings.

12/17/14: Regular checks and readings. Completed a water service line inspection at 28567 E 163rd Pl.

12/19/14: Regular checks and readings. Began valve exercising and fire hydrant flushing in all 3 subdivisions.

12/22/14: Regular checks and readings. Continued valve exercising and fire hydrant flushing in all 3 subdivisions.

12/23/14: Completed valve exercising and fire hydrant flushing in all 3 subdivisions. Completed a water service line inspection at 31425 E 162nd Ave.

12/24/14: Regular checks and readings.

12/26/14: Regular checks and readings.

12/29/14: Regular checks and readings.

12/31/14: Regular checks and readings.

Nov 21st – Dec 31st

RO Run Time Hrs	218.80 hrs
RO Concentrate Flow – 1 pond	433,224 gallons

Monthly Testing	**TDS**	**Calcium**	**Magnesium**	**Total Hardness**
BE	417 mg/L	35.1 mg/L	6.8 mg/L	115.3 mg/L
RHF	552 mg/L	59.4 mg/L	11.2 mg/L	194.5 mg/L
GRN	651 mg/L	92.6 mg/L	16.6 mg/L	299.7 mg/L