Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
July 20th – August 21st

7/20/15: Regular checks and readings.

7/22/15: Regular checks and readings. Completed a locate at 16650 Umpire St.

7/24/15: Regular checks and readings.

7/27/15: Regular checks and readings.

7/29/15: Regular checks and readings. Completed a water service line inspection at: 16355 Queensview St.

7/31/15: Regular checks and readings. Completed a locate at 16645 Joppa Ct.

8/3/15: Regular checks and readings. Increased the chlorine pump rate from 0.55 to 0.75.

8/5/15: Regular checks and readings. Completed at locate at 16280 Del Ray Ct.

8/7/15: Regular checks and readings.

8/10/15: Regular checks and readings. Collected and delivered monthly samples and TTHM and HAA5. Checked all the generators.

8/12/15: Regular checks and readings.

8/14/15: Regular checks and readings. Completed locates at: 16285 Queensview and 30125 E 166th Ave.

8/17/15: Regular checks and readings. Jeff completed quarterly walk through of facilities with Brad, Lisa and John.

8/19/15: Regular checks and readings. Collected and delivered TDS and hardness samples. Flushed Kenuil Ct fire hydrant.

8/21/15: Regular checks and readings. Installed new RO prefilters.

Operations Maintenance issues:

- **Status of valve box inserts and markers project –** *still in progress*
- **RHF leaking radiator –** *District Counsel working on drafting agreement to have Rocky Mountain Power Generation complete work as originally quoted.*

July 17th – August 21st

RO Run Time Hrs	162.80 hrs
RO Concentrate Flow – 1 pond (North)	322,344 gallons

7/10/15

Monthly Testing	TDS(mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness(mg/L)
BE	417	42.1	7.6	136.2
RHF	449	48.9	8.9	158.8
GRN	468	48.2	8.8	156.5