

Forest View Acres Water District

Operations Report – January 29, 2009

Prepared by

Erik Tameler, Southwest Water Co.

Sampling:

The required December samples were collected. Results are available for review.

Treatment Plants:

Arapahoe Water Plant:

Currently inactive.

Transmission Line/Booster Station:

AmWest (Devin Cary) was contacted regarding alarm capability for the booster station. Recommendations to follow.

Surface Water Plant:

The secondary filters were serviced by DP Solutions on Jan. 15th. Media replenishment was recommended. Pricing to follow.

Backwashing experimentation appears to be saving a significant volume of water and not compromising filter quality. We plan on continuing with the current BW plan.

Distribution system:

There were no main breaks since the last meeting.

The meter pit at 2450 Lake Meadow Dr was inspected on 1/15 and meets district specifications. A meter has not yet been set.

The 18015 StoneView Rd tap was made on 1/13. The meter pit was not up to district specifications as of 1/16. The homeowner would like the meter set ASAP.

The meter pit at 4590 Red Rock Ranch Rd was inspected on 1/15. The pit was not completely backfilled at the time of the inspection, but otherwise, met district specs.

An hourly rate for inspecting hydrants, locating valves, etc. was obtained from Renegade Systems.

An hourly rate schedule for distribution system work was obtained from Quality Pipe Services.

The water meter and remote reader were replaced at 18505 Clovenhoof Dr.

Miscellaneous:

A letter was received from CDPHE regarding the Nov. 22 chlorination system failure. Tier 2 reporting was also completed and forwarded to CRS for distribution.

