

Forest View Acres Water District

Operations Report – January 28, 2010

Prepared by Erik Tameler, Southwest Water Co.

Sampling:

The required samples were collected for Routine Coliform. Received results are inside the yellow folder in the Arapahoe treatment plant.

Treatment Plants:

Arapahoe Water Plant:

Has been operating normally. Currently off-line.

Transmission Line/Booster Station:

Normal Operation.

Surface Water Plant:

The new filters have been installed and the media in the secondary filters was replenished. The secondary filter backwash rate valve was not functioning properly and was also repaired while Aqueous Solution was on site. The plant is running very well, requiring backwashing only every second day. HACH annual Service for the turbidimeters is scheduled for Friday, Jan. 22.

Distribution system:

No breaks or leaks reported.

Miscellaneous:

The report for the CDPHE Sanitary survey was received. There is primarily one item that needs to be addressed. The backflow device in the Surface Plant will have to be replaced as has been the assumption since it was originally inspected by Dutchman Backflow in 2008. In addition to this, there were several items requiring responses, primarily for clarification. A detailed response to the survey is being prepared.

Snow removal was contracted through Sharpest Cut Landscaping.