

Forest View Acres Water District

Operations Report – February/March, 2010

Prepared by

Erik Tameler, Southwest Water Co.

Sampling:

The required samples were collected for Routine Coliform and Quarterly TTHM/HAA5's. Received results are inside the yellow folder in the Arapahoe treatment plant.

Treatment Plants:

Arapahoe Water Plant:

Has been operating normally. Currently off-line.

Transmission Line/Booster Station:

Normal Operation.

Surface Water Plant:

The plant is running very well, requiring backwashing only every third or fourth day. However, production is down due to leaks in the raw water line in the canyon. Repairs will be conducted when the inlet valve thaws this spring. Plant turbidimeters were serviced by HACH.

Distribution system:

No breaks or leaks reported.

Miscellaneous:

The replacement of the Surface Plant backflow device is tentatively scheduled for the week of March 22nd.

There were several residential "freeze ups" in February.

PRV's were inspected and are functioning normally.

Curb stop and service line records have been consolidated and placed in a new book in the Arapahoe plant office.

Filter aid and disinfectant were delivered to the plants.

