

Forest View Acres Water District

Operations Report – May, 2010

Prepared by Erik Tameler, Southwest Water Co.

Sampling:

- The required samples was collected for Routine Coliform, Disinfection Byproducts, Inorganics, Fluoride, Nitrate, and Nitrite. Received results are inside the yellow folder in the Arapahoe treatment plant.

Treatment Plants:

Arapahoe Water Plant:

- Has been operating normally.
- Well level readings have been taken and are on file. The spreadsheet has not been updated, however, results have been relatively consistent with the previous month.

Transmission Line/Booster Station:

- Normal Operation.

Surface Water Plant:

- Secondary filter #2 was serviced on May 4th. Two damaged laterals were found, which were causing premature break-through and media loss. Experimentation with the plant is on going, however, the intermittent shutdown issues have not been resolved. For this reason, at this time the plant is only being operated under supervision. At such time as I feel more comfortable with the plant, it will be operated unattended.
- Repairs to the raw water line were completed on May 11th. Service and pressure have been restored.

Distribution system:

- No breaks or leaks reported.

Miscellaneous:

- Replacement of the Surface Plant backflow device is complete. The device was not fitted with a drain funnel, which is needed. I am looking in to having the funnel installed.
- Specialty Resources Ltd. was contacted regarding the bill submitted for the quotations received. It was agreed that two service calls for \$95 each will be charged instead, with the agreement the district proceeds with the installation of moisture control as quoted.