

Forest View Acres Water District

Operations Report –July/August 2014
Prepared by Gabrielle Begeman
ORC Water Professionals

Arapahoe Water Plant

- The plant has been exercised every month at minimum.

Surface Water Plant

- The plant has been running consistently producing all of the demand of the district since the previous report.
- Please see the attached quote for roof, siding, soffit and fascia.
- The fire mitigation tree trimming has been completed.

Distribution System

- Discuss status of distribution line as it exits the booster station.
- Discuss the inclusion and potential tie-in options for a property owner in the SE corner of the district.
- Please see the production spreadsheet attached for total production, usage and percentage discrepancy.

Year	Month	SWTP Production	SWTP Production -BW	% of Total	AWP Production	% of Total	Total Production	Total Home Metered Water Usage	Tank level AWP	Gallons Gain/Loss in Tank	Gallons Metered with Tank Level Shift Loss or gain	Percentage Discrepancy	
2014	Jan	1782610	1759510	91.85%	156227	8.15%	1915737	1101800	22.30	16900	1118600	41.61%	
	Feb	1520399	1493299	99.54%	6829	0.46%	1500128	1057000	23.50	8400	1065400	28.98%	
	Mar	1408893	1378593	99.86%	1919	0.14%	1380512	1013700	22.80	273600	1287300	6.75%	
	Apr	1483773	1342173	93.63%	91382	6.37%	1433555	1053900	19.80	-30000	1023900	28.58%	
	May	1589117	1270717	80.70%	303980	19.30%	1574697	1217400	18.40	-61200	1156200	26.58%	
	Jun	1428469	1115669	38.27%	1799565	61.73%	2915234	2115500	19.00	-45600	2069900	29.00%	
	Jul	2216364	2047364	93.28%	147386	6.72%	2194750	1907800	22.20	28800	1936600	11.76%	
	Aug												
	Sep												
	Oct												
	Nov												
	Dec												
Total	TOTAL	11,429,625	10,407,325	85.30%	2,507,288	14.70%	12,914,613	9,467,100				24.75%	