

Forest View Acres Water District

Operations Report –August/September 2014
Prepared by Gabrielle Begeman
ORC Water Professionals

Arapahoe Water Plant

- The plant has been exercised every month at minimum.
- The online instrumentation has had its annual servicing.
- I hope to have a quote for installation of balusters by the meeting.
- In June 2014, the inlet at the SWTP filled with sediment, requiring the AWP to run more often to keep up with demand.
- In June 2014, the booster station failed to come on as required and lost an estimated 600,000 gallons to waste.

Surface Water Plant

- The plant has been running consistently producing most of the demand of the district since the previous report.
- The flows began to drop off mid month August. We immediately cleaned the gravel and debris from the inlet structure and flows returned to normal. Cleaning the inlet structure will be done at least 2x per year to maintain adequate flows.
- The online instrumentation has had its annual servicing.

Distribution System

- We have attempted to locate most of the lines in the Villas project area.
- The Villas project is moving along with minor hiccups.
- The meters spec'd for the Villas project are obsolete and will no longer be available within a projected 6-month time frame. The replacement system is 2.5-3x more expensive with no real benefit. I hope to have some other options available at the meeting.
- Please see the attached production report.