

Forest View Acres Water District

Operations Report –January 2015
Prepared by Gabrielle Begeman
ORC Water Professionals

Arapahoe Water Plant

- The plant has been exercised weekly.

Surface Water Plant

- The plant has been producing the majority of flow demand for the month of January.
- All of the backwash pond modifications are complete.
- Due to the hammering of the recycle pump on the piping, new structural bracing will be installed to protect the piping and prevent it from moving as much.
- The booster pump project is complete.
- The driveway will require some re-grading and rock work to avoid sliding into the new backwash pond.

Distribution System

- The inoperable fire hydrant on Pixie Park just South of Limestone has been replaced.
- The valve boxes in Limestone have been lowered so that the valves are accessible and operable.
- We found one of the 3 service lines on Rockbrook utilizing the plastic pipeline locator mentioned in the December Ops report. JDS has a plan for the other two that ORC agrees with.
- Please see the production report for December 2014 and January 2015.