

Forest View Acres Water District

Operations Report –May 2015

Prepared by Gabrielle Begeman
ORC Water Professionals

Arapahoe Water Plant

- The plant has been producing 99% of demand for May.
- Please see the attached bid for finishing the piping and control work for utilizing finished water for the backwash to the filters. The controls portion of the work is estimated to be \$1250 in addition to Applied Ingenuities bid.

Surface Water Plant

- The plant has been shut down due to high turbidities and massive rainfall.
- The electric actuated valve failed and must be replaced to be operational. Please see the attached quote for replacing this valve.
- The backwash pond needs to have a swale and erosion control blanket and sock installed. I hope to have bid from J&K prior to the meeting.

Distribution System

- I hope to have a price on installation of meter pits from J&K before the meeting.
- Please see the production report for May 2015.

Year	Month	SWTP Production - BW	% of Total	AWP Production	% of Total	Total Production	Total Water Sold	Percentage Discrepancy
2015	Jan	1,534,470	91%	143,997	9%	1,678,467	1,099,900	34.47%
	Feb	1,681,835	99%	8,748	1%	1,690,583	1,244,700	26.37%
	Mar	1,498,672	85%	263,999	15%	1,762,671	1,183,000	32.89%
	Apr	1,062,956	75%	347,206	25%	1,410,162	1,121,600	20.46%
	May	17,504	1%	1,632,343	99%	1,649,847	1,301,887	21.09%
	Jun							
	Jul							
	Aug							
	Sep							
	Oct							
	Nov							
	Dec							
Total		8,599,233	92%	763,950	8%	9,363,183		

Production Report

