

Forest View Acres Water District

Operations Report – July 2015

Prepared by Mike Kielma

ORC Water Professionals

Arapahoe Water Plant

- The plant produced 59% of demand for July. Please note that the overall year to date production from the AWP is still only 8%

Surface Water Plant

- The plant ran daily during the month of July, producing 41% of demand
- The inlet screen was cleaned again during the month
- Washed down the walls, and vacuumed the debris out of the backwash pond

Distribution System

- Global Underground replaced PRV #2 in late June, PRV #5 in July, and PRV #4 is scheduled for the second week of September
- J&K cut and capped the connection between the old transmission line and Pixie Park.
- Please see the production report for July 2015

Other

- Supplies for the backwash pond at the Surface Water Plant