



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

September 24, 2014

Steve Davis, Approvals Manager
AK Industries
P.O. Box 640, 2055 Pidco Drive
Plymouth, IN 46563

Subject: Models, S-1000, S-1050, S-1300 Septic Tank - Acceptance
For Use in Colorado On-site Wastewater Treatment Systems

Dear Mr. Davis:

Pursuant to section 43.13 of the On-site Wastewater Treatment System Regulation 5 CCR 1002-43 (Regulation 43), the Water Quality Control Division (Division) has reviewed drawings and specifications received April 21, 2014 and September 4, 2014 for the following septic tank(s) from AK Industries:

- Model S 1000
- Model S 1050
- Model S 1300

The Division finds the tank design to be consistent with the criteria of section 43.9 of Regulation 43. The Division also provides this acceptance of the tank(s) referenced above as meeting these criteria and acceptable for use in Colorado.

The materials reviewed included evidence that the tanks are certified for use as a septic tank by the International Association of Plumbing and Mechanical Officials (IAPMO), therefore watertightness testing is not required pursuant to section 43.13(G)(2). However we are requesting that you provide the Division a copy of your updated IAPMO certification on an annual basis.

This acceptance does not constitute an endorsement of this product. As individual local public health agency regulations may be more stringent than Regulation 43, the Division cannot ensure the acceptance of a septic tank within any given jurisdiction.

If you have any questions regarding the Division's review or findings, please contact me at (303) 692-2366 or chuck.cousino@state.co.us.

Sincerely,

Charles J. Cousino, REHS
On-site Wastewater Treatment System Coordinator
Engineering Section
Water Quality Control Division
Colorado Department of Public Health and Environment

cc: Local Public Health Agencies
Files

