

**TOWN OF BROOKSIDE 2014 Drinking Water Quality Report  
For Calendar Year 2013**

*Public Water System ID: CO0122050*

**Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.**

We are pleased to present to you this year’s water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. Please contact RENEE BOLKEMA at 719-276-3436 with any questions about the Drinking Consumer Confidence Rule (CCR) or for public participation opportunities that may affect the water quality.

**General Information: The Canon City Water Department provides our water. Please see enclosed Canon City Report for this information.**

**Lead in Drinking Water: The Canon City Water Department provides our water. Please see enclosed Canon City Report for this information.**

**Source Water Assessment and Protection (SWAP)**

The Colorado Department of Public Health and Environment has provided us with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit <http://wqcdcompliance.com/ccr>. The report is located under “Source Water Assessment Reports”, and then “Assessment Report by County”. Select FREMONT County and find 122050; BROOKSIDE TOWN OF or by contacting RENEE BOLKEMA at 719-276-3436. The Source Water Assessment Report provides a screening-level evaluation of potential contamination that *could* occur. It *does not* mean that the contamination *has or will* occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Potential sources of contamination in our source water area are listed on the next page.

Please contact us to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Consumer Confidence Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.

**Our Water Sources**

<u>Source</u>	<u>Source Type</u>	<u>Water Type</u>	<u>Potential Source(s) of Contamination</u>
PURCHASED SW FROM CANON CITY CO0122100	CC	SW	

**Terms and Abbreviations : See enclosed Canon City Consumer Confidence Report**

### Detected Contaminants

THE TOWN OF BROOKSIDE routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2013 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report.

**Note:** Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section then no contaminants were detected in the last round of monitoring.

<b>Lead and Copper Sampled in the Distribution System</b>								
Contaminant Name	Time Period	90 <sup>th</sup> Percentile	Sample Size	Unit of Measure	90 <sup>th</sup> Percentile AL	Sample Sites Above AL	90 <sup>th</sup> Percentile AL Exceedance	Typical Sources
Copper	07/24/2012 to 07/24/2012	0.16	5	ppm	1.3		No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	07/24/2012 to 07/24/2012	1	5	ppb	15		No	Corrosion of household plumbing systems; Erosion of natural deposits

### Violations, Significant Deficiencies, and Formal Enforcement Actions

<b>No Violations or Formal Enforcement Actions</b>
--