



# COLORADO

## Department of Public Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

October 5, 2015

Tim Copeland, Owner  
Copeland Concrete, Inc.  
28803 Hwy 6  
Rifle, CO 81650

Subject: Precast Septic Tank Submittal - Acceptance  
For Use in Colorado On-site Wastewater Treatment Systems

Dear Mr. Copeland:

Pursuant to section 43.13 of the On-site Wastewater Treatment System Regulation 5 CCR 1002-43 (Regulation 43), the Water Quality Control Division (Division) has reviewed drawings and specifications received October 5, 2015, for the following septic tanks:

- 1000 Gallon, double compartment
- 1250 Gallon, double compartment
- 1500 Gallon, double compartment
- 2000 Gallon, double compartment
- 3000 Gallon, double compartment

The Division finds the tank design to be consistent with the criteria of section 43.9 of Regulation 43. The Division also provides this acceptance of the tanks referenced above as meeting these criteria and acceptable for use in Colorado.

Note: Pursuant to section 43.13(G)(2), at least five percent of tanks must be tested for water-tightness at the manufacturing facility. A summary of testing results must be submitted to the Division on an annual basis (by February 15, each calendar year). The testing results submittal form is available on the Division website

This acceptance does not constitute an endorsement of this product. As individual local public health agency regulations may be more stringent than Regulation 43, the Division cannot ensure the acceptance of a septic tank within any given jurisdiction.

If you have any questions regarding the Division's review or findings, please contact me at (303) 692-2366 or [chuck.cousino@state.co.us](mailto:chuck.cousino@state.co.us).

Sincerely,

Charles J. Cousino, REHS  
On-site Wastewater Treatment System Coordinator  
Engineering Section  
Water Quality Control Division  
Colorado Department of Public Health and Environment

cc: Files

