Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
Oct 27th – Nov 21st

10/20/14: Jeff Rabas and operator onsite with Contractors to fix curb stops in RHF.

10/27/14: Regular checks and readings.

10/29/14: Regular checks and readings.

10/31/14: Regular checks and readings. .

11/3/14: Regular checks and readings.

11/5/14: Regular checks and readings.

11/7/14: Regular checks and readings. Completed a water service line inspection at 31320 E 163rd Ave.

11/10/14: Regular checks and readings.

11/12/14: Regular checks and readings.

11/14/14: Regular checks and readings. Sealed the hole around drain on pump #2 at Greatrock North. Pulled the mixer from the brine pond for the winter and checked the oil and fuel in the generators. Ordered 200 gallons of fuel for GRN generator it was just below 50%.

11/17/14: Regular checks and readings. Timberline Electric onsite to install new pressure sensors on RO unit. Collected and delivered monthly samples. Fuel delivered for GRN generator.

11/19/14: Regular checks and readings. Cleaned the filters on the VFD's.

11/21/14: Regular checks and readings.

Oct 27th – Nov 21st

RO Run Time Hrs	35.8 hrs
RO Concentrate Flow – 1 pond	70,884 gallons