Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
July 1st – July 17th

7/1/15: Regular checks and readings.

7/3/15: Regular checks and readings.

7/6/15: Regular checks and readings.

7/8/15: Regular checks and readings.

7/10/15: Regular checks and readings. Collected and delivered TDS and hardness samples. Checked all generators.

7/13/15: Regular checks and readings. Collected and delivered monthly total coliform samples.

7/14/15: Regular checks and readings. Delivered and assembled shelving. Pumped alluvial 1 meter vault.

7/17/15: Regular checks and readings. Mixed RO antiscalent. Completed a water line inspection at 31485 E 162nd Ave and 31539 E 164th Ave.

Operations Maintenance issues:

- **Status of valve box inserts and markers project –** *still in progress*
- **RHF leaking radiator –** *looking for additional direction from Lisa.*

June 29th – July 17th

RO Run Time Hrs	114.40 hrs
RO Concentrate Flow – 1 pond (North)	226,512 gallons

6/10/15 *(**July samples collected on 7/14 – results available next report)*

Monthly Testing	TDS(mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness(mg/L)
BE	369	28.6	5.0	92.0
RHF	350	24.4	4.1	78.0
GRN	341	25.2	4.2	80.1