Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
December 17th - January 25th

12/17/12: Regular checks and readings. Concentrate pond level increased by 1/8".

12/18/12: Regular checks and readings. Collected and delivered monthly samples.

12/19/12: Regular checks and readings. Concentrate pond level increased by 3/8".

12/21/12: Regular checks and readings. Concentrate pond level increased 1/8".

12/24/12: Regular checks and readings. Replaced the pump tubing on the chlorine pump. Mixed RO antiscalent.

12/26/12: Regular checks and readings. Concentrate pond level has increased 1 inch from start.

12/28/12: Regular checks and readings. Concentrate pond level has not changed. Install new filters in RO prefilter.

12/31/12: Regular checks and readings.

1/2/13: Regular checks and readings. Concentrate pond level has not changed. Contacted Timberline Electric due to SCADA not communicating.

1/4/13: Regular checks and readings. Concentrate pond level decreased by ¼". Reduced Laramie Fox Hills well from 57-54. Flow = 42gpm.

1/7/13: Regular checks and readings. Concentrate pond level has not changed. Filled the chlorine tank.

1/9/13: Regular checks and readings. Collected and delivered monthly samples.

1/14/13: Regular checks and readings. The SCADA system was not communicating.

1/15/13: Additional site visit with Timberline Electric to troubleshoot SCADA.

1/16/13: Regular checks and readings.

1/18/13: Regular checks and readings.

1/21/13: Regular checks and readings.

1/23/13: Regular checks and readings. Responded to water leak at 16685 Strollway St. Repaired water meter.

1/25/13: Regular checks and readings.

Concentrate Pond