

CITY OF IDAHO SPRINGS FIRE PROTECTION APPLICATION



CITY OF IDAHO SPRINGS
1711 Miner Street
P.O. Box 907
Idaho Springs, CO 80452-0907
Telephone (303) 567-2400
FAX (303) 567-0124

PERMIT FEE: \$50.00

Applicant: _____

Address: _____

FIRE PROTECTION TAPS

Number Requested: _____

Size Requested: _____

Locations: _____

Residential: Commercial: Number of Dwelling Units Planned: _____

A backflow preventer is required. Please provide all information on your backflow device. Please get your device inspected on a regular basis.

Signature: _____

Applicant

Date

WATER TAPS

Number Approved: _____

Size Approved: _____

Signature: _____

Public Works Director

Date

Fees: _____ Water @ _____ = \$ _____

TOTAL FEE \$ _____

Date Paid _____

Signature: _____

City Representative

Date

Sec. 12-113. Fire protection.

The right to tap a City main or to take and use water from the City system for private fire protection service other than from a hydrant is granted only upon all of the following conditions:

- (1) License. The owner has secured a license for such tap or service from the City and has paid an administrative fee in an amount set forth in the City's fee schedule.
- (2) From service line. If the water for fire protection is to be supplied through the same service line through which water is supplied for other purposes for the licensed premises, the fire protection facilities shall include a meter and backflow prevention equipment conforming to the design standards, and shall be installed so as to prevent the use of water through such fire protection facilities for any purpose other than fighting fires.
- (3) Adequacy of service. The City assumes no obligation or responsibility for adequacy of private fire protection service.
- (4) Limited use. The only use for which water may be taken from private fire protection facilities under license is to extinguish fires. Any other use of water, except for routine testing, from such facilities shall be deemed unauthorized use of water for which a license for fire protection service may be suspended or terminated.
- (5) Flow detection. Fire protection systems served by a service line dedicated to fire protection shall be equipped with a flow detection device and backflow prevention equipment as specified in the design standards.

(Ord. 8 §1, 2006)