

**WEEKLY
IMPOUNDMENT DEPTH, LINER & DIVERSION STRUCTURE INSPECTION FORM**

Facility Name: _____

Week	Date	Impoundment I.D.	Impoundment Liner	Diversion Structures	Impoundment Depth		Surplus or Deficit (1) - (2)	Comments
			LINER Condition and Comments	DIVERSION STRUCTURE(s)* Condition and Comments	(1) Depth level required to hold 25-yr, 24-hr or Chronic storm **	(2) Impoundment Depth Reading TODAY		
Week 1	5/1/2008	EXAMPLE Pond 1	fill & compact eroded area on Pond 1 berm	mow weeds, fill & compact holes and eroded areas	4.0 ft.	3.8 ft.	0.2 ft.	schedule land application right away
1								
2								
3								
4								
5								
1								
2								
3								
4								
5								
1								
2								
3								
4								
5								
1								
2								
3								
4								
5								
1								
2								
3								
4								
5								

* Diversion structures include: stormwater run-on diversion devices, runoff diversion structures, animal waste storage structures, and devices channelling process wastewater to impoundments or tanks.

** Wastewater impoundments must be designed, constructed and maintained to be capable of storing, at a minimum, the volume of all liquid manure and wastewater, including the runoff resulting from a 25-year, 24-hour storm or Chronic Storm, whichever is greater, plus two (2) feet of freeboard. (Reg 61.17(8) and Reg 81.6)