



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

January 14, 2015

Mr. Ken Lambert, Manager
Green Bros. Ready Mix
19441 U.S. Hwy 34
Fort Morgan, CO. 80701

Subject: 1,000 and 1,500 Gallon Septic Tank - Revised Acceptance
For Use in Colorado On-site Wastewater Treatment Systems

Dear Mr. Allen:

Pursuant to section 43.13 of the On-site Wastewater Treatment System Regulation 5 CCR 1002-43 (Regulation 43), the Water Quality Control Division (Division) has reviewed drawings and specifications received February 24, August 18, September 10, 2014, and January 7, 2015, for the following septic tank(s):

- 1,000 gallon, double compartment
- 1,500 gallon, double compartment

The Division finds the tank design to be consistent with the criteria of section 43.9 of Regulation 43. The Division also provides this acceptance of the tank(s) referenced above as meeting these criteria and acceptable for use in Colorado.

Further note that pursuant to section 43.13(G)(2), at least five percent of tanks must be tested for watertightness at the manufacturing facility. A summary of testing results must be submitted to the Division on an annual basis (February of each year). The testing results submittal form is available on the Division website.

This acceptance does not constitute an endorsement of this product. As individual local public health agency regulations may be more stringent than Regulation 43, the Division cannot ensure the acceptance of a septic tank within any given jurisdiction.

If you have any questions regarding the Division's review or findings, please contact me at (303) 692-2366 or chuck.cousino@state.co.us.

Sincerely,

Charles J. Cousino, REHS
On-site Wastewater Treatment System Coordinator
Engineering Section
Water Quality Control Division
Colorado Department of Public Health and Environment

cc: Files

