




F 465

Back Flow Preventor (device)



All facilities have a back flow preventer in the basement. But it is on the wrong side of the water system (boiler) for our intent and purposes.



Back flow device in place.



Back flow device missing.





Back flow device missing. Old style shower head.



New style shower head with built in back flow device.



*Built in back flow device.
Keep parts list.*



Mop Room. Back flow device in place.





Mop Water Sink. Tall version.



*Dirty Utility Room.
Mop water sink. Round version.*



Flat version.



Back flow device at ceiling.





Closer look at ceiling back flow device at ceiling.



Wall mounted. Different version.



Water faucet connector. Not a back flow device.



Back flow device (note holes).





Newest version. Note multiple holes.

