

Received Date:	Permit Number:
Received By:	Address:
 TOWN OF ESTES PARK www.estes.org 970-577-3726 PO Box 1200 170 McGregor Ave Estes Park, CO 80517	HYDRONICS PIPING INSTALLATION AFFIDAVIT OF COMPLIANCE Town of Estes Park Division of Building Safety

The following conditions must be met before submitting an Affidavit:

- The contractor shall be pre-approved by the Chief Building Official
- The work shall be authorized by the appropriate permit
- The work shall be associated with an approved system
- The affidavit shall be on a form provided by the CBO

Check the statements that apply:

- The Division has pre-approved the hydronic piping installation to be completed without inspection.
- The installing contractor shall sign this affidavit. The affidavit shall be left in the permit pack on site.
- The work and conditions described on the permit and approved plan matches the field installation.
- The tubing is a proprietary product; a copy of the installer's certification is on file with the Division.
- Support has been provided at 32" OC max horizontally with allowances for expansion and movement.
- All fittings and valves in place are compatible with the piping.
- There are no splices in piping loops.
- A minimum of 18-inches of metallic or other approved tubing is between the water heater and tubing.
- Hose bibs are not supported by PEX tubing. Hose bibs are anchored to prevent strain on PEX tubing.
- Tubing is located at least 6-inches horizontally and 12-inches vertically from sources of high heat.
- Tubing is free of gouges, cuts, deep scratches, tat, kinks, grease, flux, and fading or discoloration.
- Tubing is protected from nail damage.
- Tubing passing through slabs or foundations have a protective sleeve.
- Thermal barrier provided for radiant floor heating system.
- The piping was tested at the required pressure with a positive result.
- (OPTIONAL) Photos of the ongoing installation have been provided.

With my signature I verify the hydronic piping installation was performed in accordance with the manufacturers' installation specifications, the 2009 IRC or the 2009 IMC and I release the Town of Estes Park from all liability*.

Contractor Signature:	Date:
Company Name:	Town Business License Number:

*A Contractors' Affidavit of Compliance shall not exempt work from corrections if the building official determines the work does not comply with the provisions of this code.