

APPENDIX A - Physical Setting Vulnerability and Total Susceptibility Scores and Ratings

Public Water System Name: IDAHO SPRINGS CITY OF				Public Water System ID: CO0110020			
Water Source ID	Water Source Name	Source Type	Physical Setting Score	Physical Setting Rating	Total Susceptibility Score	Total Susceptibility Rating	
CO0110020-003	CHICAGO CREEK INTAKE	SW	54.5	Moderate	55.2	Moderate	
CO0110020-002	SURFACE WATER SECONDARY INTAKE	SW	56	Moderate	52.57	Moderate	

APPENDIX B - Physical Setting Vulnerability Independent Variables and Input Data

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
		Water Source Type: SW	
Variable Name	Data Value	Data Value Source	
Access Restrictions	UNK	DEFAULT	
Age of Diversion Structures	25	DEFAULT	
Age of Intake Structure	25	DEFAULT	
Annual Average Precipitation within SWAA	20.7	DATABASE	
Area of SWAA	13.4457	DATABASE	
Emergency Plan for SW Intake	UNK	DEFAULT	
Maintenance of Diversion Structure	5	DEFAULT	
Maintenance of Intake Structure	5	DEFAULT	
Multiple Intake Level	UNK	DEFAULT	
Soil Infiltration Rate of SWAA	3	DATABASE	
Use of Diversion Structures	UNK	DEFAULT	
Vegetative Cover of SWAA	95.124378	DATABASE	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
		Water Source Type: SW	
Variable Name	Data Value	Data Value Source	
Access Restrictions	UNK	DEFAULT	
Age of Diversion Structures	25	DEFAULT	
Age of Intake Structure	25	DEFAULT	
Annual Average Precipitation within SWAA	19.62	DATABASE	
Area of SWAA	43.6641	DATABASE	
Emergency Plan for SW Intake	UNK	DEFAULT	
Maintenance of Diversion Structure	5	DEFAULT	
Maintenance of Intake Structure	5	DEFAULT	
Multiple Intake Level	UNK	DEFAULT	
Soil Infiltration Rate of SWAA	3.1	DATABASE	
Use of Diversion Structures	UNK	DEFAULT	
Vegetative Cover of SWAA	81.180846	DATABASE	

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020			
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002		Water Source Type: SW	
Facility Name	Facility ID	Facility Type	Susc Score	Threat Rating	
ARDEN	0080190143	MASMIL	62.24	High	
ARGENTINE	0080190144	MASMIL	59.68	High	
BEAR CREEK & LITTLE BOSS	0080190205	MASMIL	62.24	High	
BI-METALIST	0080190254	MASMIL	65.88	High	
CENTRAL CITY-CLEAR CREEK	COD980717557	NPLRF	65.28	High	
Clear Creek Composting Faci	019-COM-005	SWSITE	63.76	High	
Idaho Springs Transfer Stat	019-TRS-005	SWSITE	64.08	High	
INTERNATIONAL	0080190814	MASMIL	62.24	High	
IRON HAT	0080190821	MASMIL	59.68	High	
LEXINGTON	0080190931	MASMIL	59.68	High	
LITTLE RICHARD	0080190955	MASMIL	62.24	High	
LITTLE WARRIOR	0080190961	MASMIL	57.12	High	
OLD SODA CREEK SCHOOL PEGMATITE	0080590141	MASMIL	65.88	High	
PACIFIC	0080191172	MASMIL	62.24	High	
SANTA FE TUNNEL	0080191309	MASMIL	62.24	High	

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020			
SEEROY CLAIMS	0080191324	MASMIL	62.24	High	
SEVENTY-SIX	0080191331	MASMIL	59.68	High	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	Water Source Type: SW		
Facility Name	Facility ID	Facility Type	Susc Score	Threat Rating	
ALEXANDER	0080190103	MASMIL	61.34	High	
ALGOT, BOBTAIL, GRACE M.	0080190105	MASMIL	61.34	High	
ALPINE	0080190115	MASMIL	56.22	High	
AMERICAN BOY	0080190117	MASMIL	58.78	High	
AMERICAN EAGLE	0080190118	MASMIL	56.22	High	
AMERICAN QUEEN	0080190120	MASMIL	61.34	High	
AQUASOURCE SERVICES & TECH INC	SARA175	SARA	58.9	High	
ARAPAHO NATIONAL FOREST	12078	TANKFAC	52.86	Moderately High	
ARGO SHAFT	0080190148	MASMIL	58.78	High	
ARGO TUNNEL	0080190149	MASMIL	61.34	High	
ARGOSY	0080190150	MASMIL	61.34	High	
ARGUS	0080190151	MASMIL	64.98	High	
BALD EAGLE	0080190187	MASMIL	61.34	High	

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020		
BANK	0080190194	MASMIL	64.98	High
BIG CHIEF SHAFT	0080190239	MASMIL	56.22	High
BIG FLAT	0080190245	MASMIL	61.34	High
BIG FORTY	0080190246	MASMIL	61.34	High
BLACK LION	0080190264	MASMIL	61.34	High
BLACKWOOD	0080190269	MASMIL	56.22	High
BOXER	0080190295	MASMIL	64.98	High
BP AMOCO #13609	15075	TANKFAC	56.3	High
BRUCE	0080190322	MASMIL	56.22	High
BRUNSWICK	0080190323	MASMIL	61.34	High
BUCKEYE	0080190328	MASMIL	56.22	High
BURNS MOORE	0080190339	MASMIL	61.34	High
C TYROL	0080190470	MASMIL	61.34	High
CALUMETT	0080190350	MASMIL	58.78	High
CAPE BRETON PITS	0080190354	MASMIL	56.22	High
CASCADE MINE	0080190364	MASMIL	61.34	High

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020		
CDOT COLO DEPT OF TRANSP.	COR000013615	HWSQG	52.26	Moderately High
CDOT EISENHOWER/JOHNSON MEMORIAL TUNNELS	2717	TANKFAC	56.14	High
CDOT HIDDEN VALLEY	1786	TANKFAC	56.14	High
CDOT IDAHO SPRINGS	7418	TANKFAC	52.86	Moderately High
CDOT IDAHO SPRINGS CSP	12340	TANKFAC	52.86	Moderately High
CECIL	0080190372	MASMIL	56.22	High
CHARTER OAK	0080190011	MASMIL	58.78	High
CHEMUNG COUNTY	0080190391	MASMIL	58.78	High
CHICAGO	0080190394	MASMIL	58.78	High
CHLORIDE,COLLATERAL	0080190397	MASMIL	58.78	High
CLEAR CREEK DISTRIBUTING	10633	TANKFAC	52.86	Moderately High
CLEAR CREEK DISTRIBUTING CO INC	13154	TANKFAC	52.86	Moderately High
CLEAR CREEK VILLAGE CONOCO	2273	TANKFAC	52.86	Moderately High
COTTON TAIL	0080190452	MASMIL	64.98	High
CSP - IDAHO SPRINGS #49612	2923	TANKFAC	52.86	Moderately High
DEFENDER LODE	0080190490	MASMIL	59.86	High

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020		
DIXIE	0080190010	MASMIL	62.42	High
DIXIE TUNNEL	0080190517	MASMIL	61.34	High
DOVE	0080190530	MASMIL	61.34	High
Echo Lake Park, D'Enver MTN Parks	599	PWSFB	56.98	High
Echo Lake Park, Denver MTN Parks	598	PWSFB	56.98	High
ECLIPSE-LOWER	0080190560	MASMIL	56.22	High
ELLA MCKENNEY	0080190578	MASMIL	61.34	High
EMMA JANE	0080190583	MASMIL	61.34	High
EVERGREEN	0080190613	MASMIL	61.34	High
FEDERAL AVIATION ADMINISTRATION	7364	TANKFAC	52.86	Moderately High
FERRELLGAS	SARA585	SARA	58.9	High
FINANCIER	0080190624	MASMIL	56.22	High
FOG STORM	0080190629	MASMIL	61.34	High
FREELAND FUNNEL	0080190645	MASMIL	61.34	High
FRENCH GIRL	0080190649	MASMIL	61.34	High
GOLD & SILVER COIN SHAFT	0080190700	MASMIL	61.34	High

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020		
GOLD ECLIPSE	0080190691	MASMIL	56.22	High
GOLDEN GLEN	0080190713	MASMIL	58.78	High
GOLDEN LIGHT TUNNEL	0080190717	MASMIL	56.22	High
HENRY WILSON	0080190771	MASMIL	61.34	High
HIDDEN VALLEY TEXACO	13961	TANKFAC	52.86	Moderately High
HIGHLAND GROUP	0080190780	MASMIL	56.22	High
HUMBOLDT	0080190796	MASMIL	64.98	High
IDAHO SPRINGS RCLR	8117	TANKFAC	52.86	Moderately High
INDIGO B	0080190811	MASMIL	58.78	High
KATIE EMMETT-UPPER	0080190864	MASMIL	61.34	High
KEARSAGE	0080190868	MASMIL	61.34	High
KING WILLIAMS	0080190890	MASMIL	61.34	High
LANCE	0080190916	MASMIL	56.22	High
LAST CHANCE	0080190018	MASMIL	56.22	High
LITTLE FLORENCE	0080190946	MASMIL	61.34	High
LITTLE TOPSY	0080190959	MASMIL	56.22	High

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020		
LIZZIE S,	0080190963	MASMIL	58.78	High
M & M SHAFT	0080191071	MASMIL	61.34	High
M & M TUNNEL	0080191072	MASMIL	61.34	High
MARBLE	0080191011	MASMIL	58.78	High
MARY FOSTER	0080191022	MASMIL	58.78	High
MAXIMILLIAN	0080191032	MASMIL	61.34	High
MINER STREET TEXACO	2423	TANKFAC	56.3	High
MOHAWK	0080191075	MASMIL	61.34	High
MOLLY BAWN MINE	0080191077	MASMIL	61.34	High
MUSCOVITE	0080191098	MASMIL	56.22	High
N' TUNNEL	0080191102	MASMIL	56.22	High
ORINOCO	0080191160	MASMIL	58.78	High
O'SHAFT	0080191136	MASMIL	56.22	High
OVIDA	0080191169	MASMIL	61.34	High
PERKINS	0080191192	MASMIL	56.22	High
PORT JARVIS	0080191213	MASMIL	64.98	High

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020		
P'TUNNEL	0080191171	MASMIL	56.22	High
Q'SHAFT	0080191233	MASMIL	61.34	High
RACHEL	0080191244	MASMIL	58.78	High
RHODA	0080191270	MASMIL	58.78	High
ROCA	0080191279	MASMIL	56.22	High
ROCKY & STONEY	0080191284	MASMIL	58.78	High
ROCKY CLIFF -LOWER	0080191283	MASMIL	56.22	High
R'TUNNEL	0080191243	MASMIL	56.22	High
SAPPHO	0080191311	MASMIL	61.34	High
SILVER BELL	0080191343	MASMIL	56.22	High
SILVER CLIFF	0080191346	MASMIL	61.34	High
SILVER HORN	0080191352	MASMIL	61.34	High
SILVER LINK	0080191359	MASMIL	61.34	High
SILVER RING	0080191368	MASMIL	56.22	High
SILVERINE	0080190064	MASMIL	62.42	High
SOUTH AMERICAN	0080191386	MASMIL	61.34	High

APPENDIX C - Individual Susceptibility Scores and Ratings for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020		
S'SHAFT	0080191298	MASMIL	58.78	High
SULITELMA	0080191414	MASMIL	58.78	High
SUMMIT	0080191416	MASMIL	56.22	High
SUMMIT OBSERVATORY	12705	TANKFAC	52.86	Moderately High
THIRTY SECOND	0080191451	MASMIL	58.78	High
TYRONE TUNNEL-LOWER	0080191489	MASMIL	61.34	High
UNKNOWN #428	0080190074	MASMIL	62.42	High
VETERAN	0080191502	MASMIL	58.78	High
VIKING	0080191511	MASMIL	58.78	High
WALLACE SHAFT	0080191519	MASMIL	58.78	High
WALLACE TUNNEL	0080191520	MASMIL	58.78	High

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: ARDEN	
Facility ID: 0080190143		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: ARGENTINE	
Facility ID: 0080190144		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: BEAR CREEK & LITTLE BOSS	
Facility ID: 0080190205		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: BI-METALIST	
Facility ID: 0080190254		Facility Type: MASMIL	
Address:		City:	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: INTERNATIONAL	
Facility ID: 0080190814		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: IRON HAT	
Facility ID: 0080190821		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: LEXINGTON	
Facility ID: 0080190931		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: LITTLE RICHARD	
Facility ID: 0080190955		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: LITTLE WARRIOR	
Facility ID: 0080190961		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: PACIFIC	
Facility ID: 0080191172		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: SANTA FE TUNNEL	
Facility ID: 0080191309		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: SEEROY CLAIMS	
Facility ID: 0080191324		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: SEVENTY-SIX	
Facility ID: 0080191331		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: OLD SODA CREEK SCHOOL PEGMATITE	
Facility ID: 0080590141		Facility Type: MASMIL	
Address:		City: JEFFERSON	
County: JEFFERSON			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: CENTRAL CITY-CLEAR CREEK	
Facility ID: COD980717557		Facility Type: NPLRF	
Address: NEAR TOWN		City: IDAHO SPGS,CENT.CY,B	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	Yes	DEFAULT	
Compliance History	Yes	DEFAULT	
Contaminant Storage	Both	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	Yes	DEFAULT	
Facility Size	> 10	DEFAULT	
Hazard Class PSOC Facility	B	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	Yes	DEFAULT	
Volume at PSOC Facility	90	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: Clear Creek Composting Faci	
Facility ID: 019-COM-005		Facility Type: SWSITE	
Address: 1.8 miles south of Idaho Springs on Soda Creek Roa		City: IDAHO SPRINGS	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Both	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	1 - 9	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	50	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	
Water Source Type: SW		Facility Name: Idaho Springs Transfer Stat	
Facility ID: 019-TRS-005		Facility Type: SWSITE	
Address: 3 mi south of Idaho Springs on Soda Lakes Road		City: IDAHO SPRINGS	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	Yes	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Both	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	1 - 9	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	50	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		
Facility Name:	CDOT COLO DEPT OF TRANSP.	Facility ID: COR000013615
		Facility Type: HWSQG
Address:	EXIT 243 HIDDEEN VALLEY I-70	City: IDAHO SPRINGS
		County:
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Active	DEFAULT
AST Presence	Yes	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Both	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	1 - 2.5	DEFAULT
Hazard Class PSOC Facility	B	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	50 - 249	DEFAULT
Pavement Conditions	Paved	DEFAULT
UST Presence	UNK	DEFAULT
Volume at PSOC Facility	30	DEFAULT
Zone (1, 2, or 3) at PSOC	3	DEFAULT
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		
Facility Name:	DIXIE	Facility ID: 0080190010
		Facility Type: MASMIL
Address:		City:
		County: CLEAR CREEK
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Active	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	70	DEFAULT
Zone (1, 2, or 3) at PSOC	2	DEFAULT

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CHARTER OAK	
Facility ID: 0080190011		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: LAST CHANCE	
Facility ID: 0080190018		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SILVERINE	
Facility ID: 0080190064		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: UNKNOWN #428	
Facility ID: 0080190074		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: ALEXANDER
Facility ID: 0080190103		Facility Type: MASMIL
Address:		City: CLEAR CREEK
County: CLEAR CREEK		
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	1	DEFAULT

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: ALGOT, BOBTAIL, GRACE M.
Facility ID: 0080190105		Facility Type: MASMIL
Address:		City: CLEAR CREEK
County: CLEAR CREEK		
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	1	DEFAULT

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ALPINE	
Facility ID: 0080190115		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: AMERICAN BOY	
Facility ID: 0080190117		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: AMERICAN EAGLE
Facility ID: 0080190118		Facility Type: MASMIL
Address:		City: CLEAR CREEK
County: CLEAR CREEK		
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	3	DEFAULT

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: AMERICAN QUEEN
Facility ID: 0080190120		Facility Type: MASMIL
Address:		City: CLEAR CREEK
County: CLEAR CREEK		
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	1	DEFAULT

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: ARGO SHAFT
Facility ID: 0080190148		Facility Type: MASMIL
Address:		City: CLEAR CREEK
County: CLEAR CREEK		
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	2	DEFAULT

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: ARGO TUNNEL
Facility ID: 0080190149		Facility Type: MASMIL
Address:		City: CLEAR CREEK
County: CLEAR CREEK		
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	1	DEFAULT

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ARGOSY	
Facility ID: 0080190150		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ARGUS	
Facility ID: 0080190151		Facility Type: MASMIL	
Address:		City:	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BALD EAGLE	
Facility ID: 0080190187		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BANK	
Facility ID: 0080190194		Facility Type: MASMIL	
Address:		City:	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BIG CHIEF SHAFT	
Facility ID: 0080190239		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BIG FLAT	
Facility ID: 0080190245		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BIG FORTY	
Facility ID: 0080190246		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BLACK LION	
Facility ID: 0080190264		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: BLACKWOOD
Facility ID: 0080190269		Facility Type: MASMIL
Address:		City: County: CLEAR CREEK
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	3	DEFAULT

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: BOXER
Facility ID: 0080190295		Facility Type: MASMIL
Address:		City: County:
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Active	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	70	DEFAULT
Zone (1, 2, or 3) at PSOC	1	DEFAULT

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BRUCE	
Facility ID: 0080190322		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BRUNSWICK	
Facility ID: 0080190323		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BUCKEYE	
Facility ID: 0080190328		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BURNS MOORE	
Facility ID: 0080190339		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CALUMETT	
Facility ID: 0080190350		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CAPE BRETON PITS	
Facility ID: 0080190354		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: CASCAD E MINE
Facility ID: 0080190364		Facility Type: MASMIL
Address:		City: County: CLEAR CREEK
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	1	DEFAULT

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: CECIL
Facility ID: 0080190372		Facility Type: MASMIL
Address:		City: County: CLEAR CREEK
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	3	DEFAULT

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CHEMUNG COUNTY	
Facility ID: 0080190391		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CHICAGO	
Facility ID: 0080190394		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: CHLORIDE, COLLATERAL
Facility ID: 0080190397		Facility Type: MASMIL
Address:		City: COUNTY: CLEAR CREEK
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Inactive	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	40	DEFAULT
Zone (1, 2, or 3) at PSOC	2	DEFAULT

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003
Water Source Type: SW		Facility Name: COTTON TAIL
Facility ID: 0080190452		Facility Type: MASMIL
Address:		City: COUNTY:
Variable Name	Data Value	Data Value Source
Active or Inactive Facility	Active	DEFAULT
AST Presence	No	DEFAULT
Compliance History	No	DEFAULT
Contaminant Storage	Outside	DEFAULT
Contaminant Transfer	Yes	DEFAULT
Evidence of Release	UNK	DEFAULT
Facility Size	2.5 - 10	DEFAULT
Hazard Class PSOC Facility	A	DEFAULT
Near/Far Zone @ PSOC	Near	DEFAULT
Number of Workers	10 - 49	DEFAULT
Pavement Conditions	Unpaved	DEFAULT
UST Presence	No	DEFAULT
Volume at PSOC Facility	70	DEFAULT
Zone (1, 2, or 3) at PSOC	1	DEFAULT

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: C TYROL	
Facility ID: 0080190470		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: DEFENDER LODE	
Facility ID: 0080190490		Facility Type: MASMIL	
Address:		City:	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: DIXIE TUNNEL	
Facility ID: 0080190517		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: DOVE	
Facility ID: 0080190530		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ECLIPSE-LOWER	
Facility ID: 0080190560		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ELLA MCKENNEY	
Facility ID: 0080190578		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: EMMA JANE	
Facility ID: 0080190583		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: EVERGREEN	
Facility ID: 0080190613		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: FINANCIER	
Facility ID: 0080190624		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: FOG STORM	
Facility ID: 0080190629		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: FREELAND FUNNEL	
Facility ID: 0080190645		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: FRENCH GIRL	
Facility ID: 0080190649		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: GOLD ECLIPSE	
Facility ID: 0080190691		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value	Source
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: GOLD & SILVER COIN SHAFT	
Facility ID: 0080190700		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value	Source
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: GOLDEN GLEN	
Facility ID: 0080190713		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: GOLDEN LIGHT TUNNEL	
Facility ID: 0080190717		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: HENRY WILSON	
Facility ID: 0080190771		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value	Source
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: HIGHLAND GROUP	
Facility ID: 0080190780		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value	Source
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: HUMBOLDT	
Facility ID: 0080190796		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: INDIGO B	
Facility ID: 0080190811		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: KATIE EMMETT-UPPER	
Facility ID: 0080190864		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: KEARSAGE	
Facility ID: 0080190868		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: KING WILLIAMS	
Facility ID: 0080190890		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: LANCE	
Facility ID: 0080190916		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: LITTLE FLORENCE	
Facility ID: 0080190946		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: LITTLE TOPSY	
Facility ID: 0080190959		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: LIZZIE S,	
Facility ID: 0080190963		Facility Type: MASMIL	
Address:		City:	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: MARBLE	
Facility ID: 0080191011		Facility Type: MASMIL	
Address:		City:	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: MARY FOSTER	
Facility ID: 0080191022		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: MAXIMILLIAN	
Facility ID: 0080191032		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: M & M SHAFT	
Facility ID: 0080191071		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: M & M TUNNEL	
Facility ID: 0080191072		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: MOHAWK	
Facility ID: 0080191075		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: MOLLY BAWN MINE	
Facility ID: 0080191077		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: MUSCOVITE	
Facility ID: 0080191098		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: N' TUNNEL	
Facility ID: 0080191102		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: O'SHAFT	
Facility ID: 0080191136		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ORINOCO	
Facility ID: 0080191160		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: OVIDA	
Facility ID: 0080191169		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: P'TUNNEL	
Facility ID: 0080191171		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: PERKINS	
Facility ID: 0080191192		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: PORT JARVIS	
Facility ID: 0080191213		Facility Type: MASMIL	
Address:		City:	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	70	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: Q'SHAFT	
Facility ID: 0080191233		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: R'TUNNEL	
Facility ID: 0080191243		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: RACHEL	
Facility ID: 0080191244		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: RHODA	
Facility ID: 0080191270		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ROCA	
Facility ID: 0080191279		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ROCKY CLIFF -LOWER	
Facility ID: 0080191283		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ROCKY & STONEY	
Facility ID: 0080191284		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: S'SHAFT	
Facility ID: 0080191298		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SAPPHO	
Facility ID: 0080191311		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SILVER BELL	
Facility ID: 0080191343		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SILVER CLIFF	
Facility ID: 0080191346		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SILVER HORN	
Facility ID: 0080191352		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SILVER LINK	
Facility ID: 0080191359		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SILVER RING	
Facility ID: 0080191368		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SOUTH AMERICAN	
Facility ID: 0080191386		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SULITELMA	
Facility ID: 0080191414		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SUMMIT	
Facility ID: 0080191416		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: THIRTY SECOND	
Facility ID: 0080191451		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: TYRONE TUNNEL-LOWER	
Facility ID: 0080191489		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: VETERAN	
Facility ID: 0080191502		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: VIKING	
Facility ID: 0080191511		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: WALLACE SHAFT	
Facility ID: 0080191519		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: WALLACE TUNNEL	
Facility ID: 0080191520		Facility Type: MASMIL	
Address:		City: CLEAR CREEK	
County: CLEAR CREEK		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	2.5 - 10	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	40	DEFAULT	
Zone (1, 2, or 3) at PSOC	2	DEFAULT	
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: Echo Lake Park, Denver MTN Parks	
Facility ID: 598		Facility Type: PWSFB	
Address: 13261 State Hwy 103		City: Idaho Springs	
County:		County:	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	ANALYST	
AST Presence	No	ANALYST	
Compliance History	No	DEFAULT	
Contaminant Storage	Inside	ANALYST	
Contaminant Transfer	Yes	ANALYST	
Evidence of Release	No	ANALYST	
Facility Size	> 10	ANALYST	
Hazard Class PSOC Facility	B	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	1 - 9	ANALYST	
Pavement Conditions	Unpaved	ANALYST	
UST Presence	Yes	ANALYST	
Volume at PSOC Facility	30	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: Echo Lake Park, DEnver MTN Parks	
Facility ID: 599		Facility Type: PWSFB	
Address: 13261 State Hwy 103		City: Idaho Springs	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	ANALYST	
AST Presence	No	ANALYST	
Compliance History	No	DEFAULT	
Contaminant Storage	Inside	ANALYST	
Contaminant Transfer	Yes	ANALYST	
Evidence of Release	No	ANALYST	
Facility Size	> 10	ANALYST	
Hazard Class PSOC Facility	B	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	1 - 9	ANALYST	
Pavement Conditions	Unpaved	ANALYST	
UST Presence	Yes	ANALYST	
Volume at PSOC Facility	30	DEFAULT	
Zone (1, 2, or 3) at PSOC	1	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: AQUASOURCE SERVICES & TECH INC	
Facility ID: SARA175		Facility Type: SARA	
Address: 23330 RIVERSIDE DR		City: IDAHO SPGS	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	Yes	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Both	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	60	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: FERRELLGAS	
Facility ID: SARA585		Facility Type: SARA	
Address: ONE FERRELL WAY		City: IDAHO SPGS	
County:			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	Yes	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Both	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Unpaved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	60	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CLEAR CREEK DISTRIBUTING	
Facility ID: 10633		Facility Type: TANKFAC	
Address: I-70 EXIT 243 , HIDDEN VALLEY		City: IDAHO SPRINGS	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: ARAPAHO NATIONAL FOREST	
Facility ID: 12078		Facility Type: TANKFAC	
Address: E FRONTAGE RD		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CDOT IDAHO SPRINGS CSP	
Facility ID: 12340		Facility Type: TANKFAC	
Address: 3000 COLORADO BLVD		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: SUMMIT OBSERVATORY	
Facility ID: 12705		Facility Type: TANKFAC	
Address: MOUNT EVANS		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CLEAR CREEK DISTRIBUTING CO INC	
Facility ID: 13154		Facility Type: TANKFAC	
Address: I-70 & EXIT 243 , HIDDEN VALLEY EXIT		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: HIDDEN VALLEY TEXACO	
Facility ID: 13961		Facility Type: TANKFAC	
Address: I-70 & EXIT 243 , HIDDEN VALLEY EXIT		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: BP AMOCO #13609	
Facility ID: 15075		Facility Type: TANKFAC	
Address: 2911 COLORADO BLVD		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	Yes	DEFAULT	
Volume at PSOC Facility	30	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CDOT HIDDEN VALLEY	
Facility ID: 1786		Facility Type: TANKFAC	
Address: I-70 MP 243.20		City: IDAHO SPRINGS	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	Yes	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	30	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	
Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CLEAR CREEK VILLAGE CONOCO	
Facility ID: 2273		Facility Type: TANKFAC	
Address: JCT I-70 & HWY 6		City: IDAHO SPRINGS	
County: CLEAR CREEK			
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: MINER STREET TEXACO	
Facility ID: 2423		Facility Type: TANKFAC	
Address: 115 13TH ST		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	Yes	DEFAULT	
Volume at PSOC Facility	30	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CDOT EISENHOWER/JOHNSON MEMORIAL TUNNELS	
Facility ID: 2717		Facility Type: TANKFAC	
Address: PO BOX AT MILE MARKER 214		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Active	DEFAULT	
AST Presence	Yes	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	Yes	DEFAULT	
Evidence of Release	UNK	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	30	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CSP - IDAHO SPRINGS #49612	
Facility ID: 2923		Facility Type: TANKFAC	
Address: 3000 COLORADO BLVD		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: FEDERAL AVIATION ADMINISTRATION	
Facility ID: 7364		Facility Type: TANKFAC	
Address: NO ST ADDRESS		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX D - Contaminant Threat Independent Variables and Input Data for Discrete Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: CDOT IDAHO SPRINGS	
Facility ID: 7418		Facility Type: TANKFAC	
Address: HWY 70 MP 241.05		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: CHICAGO CREEK INTAKE		Water Source ID: CO0110020-003	
Water Source Type: SW		Facility Name: IDAHO SPRINGS RCLR	
Facility ID: 8117		Facility Type: TANKFAC	
Address: HWY 103 - SQUAW PASS		City: IDAHO SPRINGS	
		County: CLEAR CREEK	
Variable Name	Data Value	Data Value Source	
Active or Inactive Facility	Inactive	DEFAULT	
AST Presence	No	DEFAULT	
Compliance History	No	DEFAULT	
Contaminant Storage	Outside	DEFAULT	
Contaminant Transfer	No	DEFAULT	
Evidence of Release	No	DEFAULT	
Facility Size	1 - 2.5	DEFAULT	
Hazard Class PSOC Facility	A	DEFAULT	
Near/Far Zone @ PSOC	Near	DEFAULT	
Number of Workers	10 - 49	DEFAULT	
Pavement Conditions	Paved	DEFAULT	
UST Presence	No	DEFAULT	
Volume at PSOC Facility	10	DEFAULT	
Zone (1, 2, or 3) at PSOC	3	DEFAULT	

APPENDIX E - Individual Susceptibility Scores and Ratings for Dispersed Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF **Public Water System ID: CO0110020**

Water Source Name: SURFACE WATER SECONDARY INTAKE **Water Source ID: CO0110020-002** **Water Source Type: SW**

Contaminant Source Type	Susceptibility Score	Susceptibility Rating
Comm Indust Total PSOC Threat	33.61	Moderate
Deciduious Forest Total PSOC Threat	34.3	Moderate
Evergreen Forest Total PSOC Threat	53.52	High
Low Intensity Res Total PSOC Threat	33.6	Moderate
Septic Count Total PSOC Threat	44.51	Moderately High
Total Road Miles PSOC Threat	45.61	Moderately High

Water Source Name: CHICAGO CREEK INTAKE **Water Source ID: CO0110020-003** **Water Source Type: SW**

Contaminant Source Type	Susceptibility Score	Susceptibility Rating
Comm Indust Total PSOC Threat	32.7	Moderate
Deciduious Forest Total PSOC Threat	34.61	Moderate
Evergreen Forest Total PSOC Threat	46.94	Moderately High
Mixed Forest Total PSOC Threat	32.81	Moderate
Septic Count Total PSOC Threat	33.73	Moderate
Total Road Miles PSOC Threat	40.16	Moderately High

APPENDIX F - Contaminant Threat Independent Variables and Input Data for Dispersed Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF		Public Water System ID: CO0110020	
Water Source Name: SURFACE WATER SECONDARY INTAKE		Water Source ID: CO0110020-002	Water Source Type: SW
Variable Name	Data Value	Data Value Source	
Comm Indust Hazard Class Z1 Near	90	DEFAULT	
Comm Indust LOR Z1 Near	60	DEFAULT	
Comm Indust Near/Far Zone @PSOC Z1 Near	Near	DEFAULT	
Comm Indust Volume Z1 Near	0.11	DATABASE	
Comm Indust Zone 1, 2, or 3 @ PSOC Z1 Near	1	DEFAULT	
Deciduious Forest Hazard Class Z1 Near	50	DEFAULT	
Deciduious Forest Hazard Class Z2 Near	50	DEFAULT	
Deciduious Forest Hazard Class Z3 Near	50	DEFAULT	
Deciduious Forest LOR Z1 Near	20	DEFAULT	
Deciduious Forest LOR Z2 Near	20	DEFAULT	
Deciduious Forest LOR Z3 Near	20	DEFAULT	
Deciduious Forest Near/Far Zone @PSOC Z1 Near	Near	DEFAULT	
Deciduious Forest Near/Far Zone @PSOC Z2 Near	Near	DEFAULT	
Deciduious Forest Near/Far Zone @PSOC Z3 Near	Near	DEFAULT	
Deciduious Forest Volume Z1 Near	4.19	DATABASE	
Deciduious Forest Volume Z2 Near	2.22	DATABASE	
Deciduious Forest Volume Z3 Near	3.13	DATABASE	
Deciduious Forest Zone 1, 2, or 3 @ PSOC Z1 Near	1	DEFAULT	
Deciduious Forest Zone 1, 2, or 3 @ PSOC Z2 Near	2	DEFAULT	
Deciduious Forest Zone 1, 2, or 3 @ PSOC Z3 Near	3	DEFAULT	
Evergreen Forest Hazard Class Z1 Near	50	DEFAULT	
Evergreen Forest Hazard Class Z2 Near	50	DEFAULT	
Evergreen Forest Hazard Class Z3 Near	50	DEFAULT	
Evergreen Forest LOR Z1 Near	20	DEFAULT	
Evergreen Forest LOR Z2 Near	20	DEFAULT	
Evergreen Forest LOR Z3 Near	20	DEFAULT	
Evergreen Forest Near/Far Zone @PSOC Z1 Near	Near	DEFAULT	
Evergreen Forest Near/Far Zone @PSOC Z2 Near	Near	DEFAULT	
Evergreen Forest Near/Far Zone @PSOC Z3 Near	Near	DEFAULT	
Evergreen Forest Volume Z1 Near	88.56	DATABASE	
Evergreen Forest Volume Z2 Near	95.01	DATABASE	
Evergreen Forest Volume Z3 Near	90.84	DATABASE	
Evergreen Forest Zone 1, 2, or 3 @ PSOC Z1 Near	1	DEFAULT	

APPENDIX F - Contaminant Threat Independent Variables and Input Data for Dispersed Contaminant Sources

Public Water System Name:	IDAHO SPRINGS CITY OF	Public Water System ID:	CO0110020
Evergreen Forest Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Evergreen Forest Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT
Low Intensity Res Hazard Class Z1 Near	50		DEFAULT
Low Intensity Res Hazard Class Z2 Near	50		DEFAULT
Low Intensity Res LOR Z1 Near	20		DEFAULT
Low Intensity Res LOR Z2 Near	20		DEFAULT
Low Intensity Res Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Low Intensity Res Near/Far Zone @PSOC Z2 Near	Near		DEFAULT
Low Intensity Res Volume Z1 Near	0.02		DATABASE
Low Intensity Res Volume Z2 Near	0.01		DATABASE
Low Intensity Res Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Low Intensity Res Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Oil & Gas Well Count Volume Z1 Near	0		DATABASE
Oil & Gas Well Count Volume Z2 Near	0		DATABASE
Oil & Gas Well Count Volume Z3 Near	0		DATABASE
Oil & Gas Well Hazard Class Z1 Near	10		DEFAULT
Oil & Gas Well Hazard Class Z2 Near	10		DEFAULT
Oil & Gas Well Hazard Class Z3 Near	10		DEFAULT
Oil & Gas Well LOR Z1 Near	40		DEFAULT
Oil & Gas Well LOR Z2 Near	40		DEFAULT
Oil & Gas Well LOR Z3 Near	40		DEFAULT
Oil & Gas Well Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Oil & Gas Well Near/Far Zone @PSOC Z2 Near	Near		DEFAULT
Oil & Gas Well Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Oil & Gas Well Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Oil & Gas Well Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Oil & Gas Well Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT
Septic Count Hazard Class Z1 Near	90		DEFAULT
Septic Count Hazard Class Z2 Near	90		DEFAULT
Septic Count Hazard Class Z3 Near	90		DEFAULT
Septic Count LOR Z1 Near	40		DEFAULT
Septic Count LOR Z2 Near	40		DEFAULT
Septic Count LOR Z3 Near	40		DEFAULT
Septic Count Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Septic Count Near/Far Zone @PSOC Z2 Near	Near		DEFAULT

APPENDIX F - Contaminant Threat Independent Variables and Input Data for Dispersed Contaminant Sources

Public Water System Name:	IDAHO SPRINGS CITY OF	Public Water System ID:	CO0110020
Septic Count Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Septic Count Volume Z1 Near	0.66		DATABASE
Septic Count Volume Z2 Near	1.18		DATABASE
Septic Count Volume Z3 Near	1.29		DATABASE
Septic Count Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Septic Count Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Septic Count Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT
Total Road Miles Hazard Class Z1 Near	50		DEFAULT
Total Road Miles Hazard Class Z2 Near	50		DEFAULT
Total Road Miles Hazard Class Z3 Near	50		DEFAULT
Total Road Miles LOR Z1 Near	40		DEFAULT
Total Road Miles LOR Z2 Near	40		DEFAULT
Total Road Miles LOR Z3 Near	40		DEFAULT
Total Road Miles Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Total Road Miles Near/Far Zone @PSOC Z2 Near	Near		DEFAULT
Total Road Miles Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Total Road Miles Volume Z1 Near	3.57		DATABASE
Total Road Miles Volume Z2 Near	1.6		DATABASE
Total Road Miles Volume Z3 Near	2.46		DATABASE
Total Road Miles Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Total Road Miles Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Total Road Miles Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT

APPENDIX F - Contaminant Threat Independent Variables and Input Data for Dispersed Contaminant Sources

Public Water System Name: IDAHO SPRINGS CITY OF **Public Water System ID: CO0110020**

Water Source Name: CHICAGO CREEK INTAKE **Water Source ID: CO0110020-003** **Water Source Type: SW**

Variable Name	Data Value	Data Value Source
Comm Indust Hazard Class Z2 Near	90	DEFAULT
Comm Indust Hazard Class Z3 Near	90	DEFAULT
Comm Indust LOR Z2 Near	60	DEFAULT
Comm Indust LOR Z3 Near	60	DEFAULT
Comm Indust Near/Far Zone @PSOC Z2 Near	Near	DEFAULT
Comm Indust Near/Far Zone @PSOC Z3 Near	Near	DEFAULT
Comm Indust Volume Z2 Near	0.01	DATABASE
Comm Indust Volume Z3 Near	0.03	DATABASE
Comm Indust Zone 1, 2, or 3 @ PSOC Z2 Near	2	DEFAULT
Comm Indust Zone 1, 2, or 3 @ PSOC Z3 Near	3	DEFAULT
Deciduious Forest Hazard Class Z1 Near	50	DEFAULT
Deciduious Forest Hazard Class Z2 Near	50	DEFAULT
Deciduious Forest Hazard Class Z3 Near	50	DEFAULT
Deciduious Forest LOR Z1 Near	20	DEFAULT
Deciduious Forest LOR Z2 Near	20	DEFAULT
Deciduious Forest LOR Z3 Near	20	DEFAULT
Deciduious Forest Near/Far Zone @PSOC Z1 Near	Near	DEFAULT
Deciduious Forest Near/Far Zone @PSOC Z2 Near	Near	DEFAULT
Deciduious Forest Near/Far Zone @PSOC Z3 Near	Near	DEFAULT
Deciduious Forest Volume Z1 Near	10.42	DATABASE
Deciduious Forest Volume Z2 Near	6.73	DATABASE
Deciduious Forest Volume Z3 Near	8.96	DATABASE
Deciduious Forest Zone 1, 2, or 3 @ PSOC Z1 Near	1	DEFAULT
Deciduious Forest Zone 1, 2, or 3 @ PSOC Z2 Near	2	DEFAULT
Deciduious Forest Zone 1, 2, or 3 @ PSOC Z3 Near	3	DEFAULT
Evergreen Forest Hazard Class Z1 Near	50	DEFAULT
Evergreen Forest Hazard Class Z2 Near	50	DEFAULT
Evergreen Forest Hazard Class Z3 Near	50	DEFAULT
Evergreen Forest LOR Z1 Near	20	DEFAULT
Evergreen Forest LOR Z2 Near	20	DEFAULT
Evergreen Forest LOR Z3 Near	20	DEFAULT
Evergreen Forest Near/Far Zone @PSOC Z1 Near	Near	DEFAULT
Evergreen Forest Near/Far Zone @PSOC Z2 Near	Near	DEFAULT

APPENDIX F - Contaminant Threat Independent Variables and Input Data for Dispersed Contaminant Sources

Public Water System Name:	IDAHO SPRINGS CITY OF	Public Water System ID:	CO0110020
Evergreen Forest Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Evergreen Forest Volume Z1 Near	69.15		DATABASE
Evergreen Forest Volume Z2 Near	69.27		DATABASE
Evergreen Forest Volume Z3 Near	55.48		DATABASE
Evergreen Forest Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Evergreen Forest Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Evergreen Forest Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT
Mixed Forest Hazard Class Z1 Near	50		DEFAULT
Mixed Forest Hazard Class Z2 Near	50		DEFAULT
Mixed Forest Hazard Class Z3 Near	50		DEFAULT
Mixed Forest LOR Z1 Near	20		DEFAULT
Mixed Forest LOR Z2 Near	20		DEFAULT
Mixed Forest LOR Z3 Near	20		DEFAULT
Mixed Forest Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Mixed Forest Near/Far Zone @PSOC Z2 Near	Near		DEFAULT
Mixed Forest Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Mixed Forest Volume Z1 Near	0.47		DATABASE
Mixed Forest Volume Z2 Near	0.3		DATABASE
Mixed Forest Volume Z3 Near	0.72		DATABASE
Mixed Forest Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Mixed Forest Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Mixed Forest Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT
Oil & Gas Well Count Volume Z1 Near	0		DATABASE
Oil & Gas Well Count Volume Z2 Near	0		DATABASE
Oil & Gas Well Count Volume Z3 Near	0		DATABASE
Oil & Gas Well Hazard Class Z1 Near	10		DEFAULT
Oil & Gas Well Hazard Class Z2 Near	10		DEFAULT
Oil & Gas Well Hazard Class Z3 Near	10		DEFAULT
Oil & Gas Well LOR Z1 Near	40		DEFAULT
Oil & Gas Well LOR Z2 Near	40		DEFAULT
Oil & Gas Well LOR Z3 Near	40		DEFAULT
Oil & Gas Well Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Oil & Gas Well Near/Far Zone @PSOC Z2 Near	Near		DEFAULT
Oil & Gas Well Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Oil & Gas Well Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT

APPENDIX F - Contaminant Threat Independent Variables and Input Data for Dispersed Contaminant Sources

Public Water System Name:	IDAHO SPRINGS CITY OF	Public Water System ID:	CO0110020
Oil & Gas Well Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Oil & Gas Well Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT
Septic Count Hazard Class Z1 Near	90		DEFAULT
Septic Count Hazard Class Z2 Near	90		DEFAULT
Septic Count Hazard Class Z3 Near	90		DEFAULT
Septic Count LOR Z1 Near	40		DEFAULT
Septic Count LOR Z2 Near	40		DEFAULT
Septic Count LOR Z3 Near	40		DEFAULT
Septic Count Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Septic Count Near/Far Zone @PSOC Z2 Near	Near		DEFAULT
Septic Count Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Septic Count Volume Z1 Near	0.19		DATABASE
Septic Count Volume Z2 Near	0		DATABASE
Septic Count Volume Z3 Near	0		DATABASE
Septic Count Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Septic Count Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Septic Count Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT
Total Road Miles Hazard Class Z1 Near	50		DEFAULT
Total Road Miles Hazard Class Z2 Near	50		DEFAULT
Total Road Miles Hazard Class Z3 Near	50		DEFAULT
Total Road Miles LOR Z1 Near	40		DEFAULT
Total Road Miles LOR Z2 Near	40		DEFAULT
Total Road Miles LOR Z3 Near	40		DEFAULT
Total Road Miles Near/Far Zone @PSOC Z1 Near	Near		DEFAULT
Total Road Miles Near/Far Zone @PSOC Z2 Near	Near		DEFAULT
Total Road Miles Near/Far Zone @PSOC Z3 Near	Near		DEFAULT
Total Road Miles Volume Z1 Near	2.03		DATABASE
Total Road Miles Volume Z2 Near	0.53		DATABASE
Total Road Miles Volume Z3 Near	0.77		DATABASE
Total Road Miles Zone 1, 2, or 3 @ PSOC Z1 Near	1		DEFAULT
Total Road Miles Zone 1, 2, or 3 @ PSOC Z2 Near	2		DEFAULT
Total Road Miles Zone 1, 2, or 3 @ PSOC Z3 Near	3		DEFAULT