Form No.
GWS-25

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

RECEIVED
NOV 26 2012

EXST

WELL PERMIT NUMBER 76860 -F -
DIV. 1 WD 1 DES. BASIN MD

APPLICANT

GREATROCK NORTH WATER & SANITATION
C/O BISHOP BROGEN ASSOCIATES
333 W HAMPDEN AVENUE STE 1050
ENGLEWOOD, CO 80110-

(303) 806-8952

APPROVED WELL LOCATION
ADAMS COUNTY
SW 1/4 SE 1/4 Section 3
Township 1 S Range 65 W Sixth P.M.

DISTANCES FROM SECTION LINES
325 Ft. from South Section Line
1800 Ft. from East Section Line

UTM COORDINATES (Meters,Zone:13,NAD83)
Easting: Northing:

CHANGE/EXPANSION OF USE OF AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
3) Approved pursuant to CRS 37-90-137(4) on the condition that this well is operated in accordance with the augmentation plans approved by the Division 1 Water Court in Case Nos. 98CW266, 99CW40, and 00CW200 as modified in case no. 08CW43. If the well is not operated in accordance with the terms of said decrees, it will be subject to administration including orders to cease diverting water.
4) The use of ground water from this well is limited to municipal, domestic, industrial, agricultural, commercial, irrigation, stock watering, recreation, fish and wildlife, fire protection, augmentation, substitution, and exchange.
5) Production is limited to the Upper Arapahoe aquifer.
6) The pumping rate of this well shall not exceed 75 GPM.
7) The allowed average annual amount of ground water to be withdrawn by this well (UKA-1) in combination with 2 other wells designated as UKA-2 and UKA-3 shall not exceed 68.89 acre-feet.
8) A geophysical log for this well is filed under permit no. 51263-F.
9) The owner shall mark the well in a conspicuous place with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
10) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
11) This well shall be located at least 600 feet from any existing well, completed in the same aquifer, that is not owned by the applicant, excluding well permit no(s). 186029, 186028 (spacing waivers submitted by the well owners).
12) This well shall be located not more than 200 feet from the location specified on this permit.
13) This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and regulations.
14) Approved for the expansion of use of an existing well with permit no. 51919-F. Permit no. 51919-F was canceled by order of the State Engineer upon approval of this permit.

APPROVED
TLK

Dick Wolfe
State Engineer

Tracy L Kolb
By

Receipt No. 3654512D DATE ISSUED 11-16-2012 EXPIRATION DATE 11-16-2013

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

NOTE: This permit will expire on the expiration date unless a pump is installed by that date. A Pump Installation and Test Report (GWS-32) must be submitted to the Division of Water Resources to verify the well has been constructed and the pump has been installed. A one-time extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: http://www.water.state.co.us TLK 11-16-12