Greatrock North WSD
Water Quality Calls 2010 - 2012

	Date	Complaint	Name	Address	Phone	Subd	Action Taken	Notes
1	02/08/10	Fluoride	Greer, Sherry	16385 Jalna Ct	303-637-9200	RHF	Discussion and forward lab results	
2	03/22/10	Brown water	Lloyd	16588 Joppa Ct.		RHF	Flush on 3/22	
3	04/02/10	Bad Hot Water Tank		16460 Tree Haven		BOX	Discussed with Rob Fleck	
4	04/26/10	Gray water turning whites gray, smelly	Roppo, Mary	16715 Shadowwood Ct	303-659-4688	BOX	Discussed with homeowner; flush on 4/28	
5	05/07/10	Brown water	Randall	16481 Tree Haven St.	303-667-7222	BOX	Asked him to run water for a few minutes to see if it would clear	
6	05/12/10	Brown water	Arnold, Brian	16530 Treehaven	303-655-8121	BOX	Flush on 5/12	
7	05/18/10	Brown water	Lovato	31305 E. 166th Ave.	303-659-2616	BOX	Flush on 5/18	
8	05/29/10	Murky water; musky smell	Paustian, Corinne	16555 Umpire Ct	303-655-1954	BOX	Asked her to run water for a few minutes to see if it would clear	
9	06/04/10	Brown water	Dahlin	16181 Rayburn St.	303-655-1289	BOX	Flush on 6/4	
10	06/04/10	Brown water	Obrechet, Ted	16651 Treehaven	303-659-1914	BOX	Flush on 6/4	
11	07/10/10	Brown water	Montoya, Jeff	31450 E 167th Ave	303-655-0606	BOX	Flush on 7/12	
12	07/15/10	Brown water	Cheserinick	32285 E. 166th Ct.	303-637-0079	BOX	Flush on 7/16	
13	07/23/10	Brown water	Frank	16261 Timber Cove St.		BOX	Flush on 7/26	
14	08/03/10	Brown water	Leonard, Travis	16720 Kenuil Ct.	303-655-3744	RHF	Flush on 8/3	
15	08/03/10	Brown water	Zaiss, Brian	31351 E 167th	303-710-0193	BOX	Flush on 8/3	
16	08/10/10	Brown water	Fleck, Rob	16460 Tree Haven St	via email	BOX	Flush on 8/10	Also 2 neighbors
17	08/12/10	Milky then brown water	Watt	29365 E. 160th Ct.	303-6551757	GN	Flush on 8/12	Caused by system losing pressure
18	08/13/10	Brown water	Campbell, Robert	28355 E. 160th Ave.	303-655-0148	GN	Flush on 8/13	Caused by system losing pressure
19	8/17/10	Brown water	Fleck, Rob	16460 Tree Haven St	via email	BOX	Waiting for controlled flush with Olsson	Also 1 neighbor
20	9/14/10						FLUSH ALL OF BOX ELDER CREEK SUBD.	
21	9/15/10	Brown water	Gerry	16290 Greatrock Way	303-325-6894	GN	Called customer	Water was not brown anymore
22	9/20/10	Brown water	Moore, Ken	16480 Timber Cove	720-685-7167	BOX	flush lines and met with customer	
23	10/4/10	Tea colored	Moore, Ken	16480 Timber Cove	303-906-1355	BOX	Flush on 10/4	
24	10/12/10	Reddish Brown	Moore, Denise	16480 Timber Cove		BOX	Inspection by Brad Simons - see Olsson memo 16480 timbercove 10-12-10.xls	
25	10/21/10	particles in water	Dahlberg, Julie	16600 Umpire Ct.	303-498-0419	BOX	flush on 10/21/10	
26	11/5/10	bad taste	Jimison, Robert	16580 Umpire St.	Stopped Katie reading meters	BOX	explained RO just went back online	Wanted to bring a jug to the District and make us drink it. Asked when are we getting our good water back? Didn't notice brown water
27	11/5/10	bad taste	Howes, Angie	16141 Rayburn St.	Stopped Katie reading meters	BOX	explained RO just went back online	Katie tasted seemed fine. Also asked when they were getting their good water back? Didn't notice brown water
28	12/8/10	Water filter turns brown very quickly	Curl, Jo Ann	29430 E 160th Ct	303-654-0132	GN	Discussed status of water looping project and present blending of RO and well water	Recent fire flows could have stirred up main lines
29	1/5/11	Update	Leonard, Travis	16720 Kenuil Ct.	303-655-3744	RHF		Katie saw Travis while reading the meters. Travis said "Thanks, the water has been good lately"
30	2/17/11	Update	Leonard, Travis	16720 Kenuil Ct.	303-655-3744	RHF	Flushed this date; water was clear	
31	2/19/11	Update	Williams, Ken	32505 E 167 Dr	303-637-0708	BOX		While responding to a call about a leak; Ken said the water has been good, no more "blue water"
32	2/21/11	Brown water	Moore, Ken	16480 Timber Cove	303-906-1355	BOX	Flush fire hydrants one South of address and one North of address on 2/22/11	Says filters are still plugging every month; if he bypasses it plugs the refrig filter
33	2/21/11	Lt Brown Water	Allain, Kimberly	16321 Timber Cove	303-637-9886	BOX	Flush Timber Cove & Umpire St. fire hydrant and the Timber Cove cul-de-sac blowoff on 2/22/11	Still slight yellow color in water; not as bad as before; mostly from hot water; told her she might want to drain the hot water tank
34	2/21/11	Brown water	Ross, Don	29957 E 166th Place	720-685-0905	RHF	Flush on 2/22/11	Water still brown, hasn't seen much improvement
35	2/22/11	Light brown water	Dahlin, Mathew	16181 Rayburn St.	303-655-1289	BOX	Flush on 2/22/11	Water has been good since last flush on 6/4/10
36	2/23/11	Blue staining in cup	Fleck, Rob	16460 Tree Haven St	via email	BOX	Langelier Index sample to lab on 2/23/11	Began adding Calciquest (Re: blue water) on 3/10/11
37	2/23/11	Much better, running clear	Ross, Don	29957 E 166th Place	720-685-0905	RHF	Flush on 2/22/11	Don called back to thank us; said the water was clear this AM
38	3/12/11	Lt Brown Water	Tario, Alma	16655 Stroilway St	303-637-0121	BOX	Flushed on 3/14/11	FH at Stroilway and 168th ran cloudy for 62 minutes at around 300 gpm
39	3/14/11	Brown water	Eberle, Doug	16640 Stroilway St	303-659-3733	BOX	Flushed on 3/14/11	The water used to be great; now it's getting worse and worse; not happy. Never seen it this bad
40	3/15/11	Brown water	Best, Dan	16785 Red Lane	303-748-1800	BOX	Flushed on 3/15/11	It's been bad all week
41	5/9/11	Horrible Taste	Fleck, Rob	16460 Tree Haven St	via Brad	BOX	No Action	
42	8/5/11	Ruining his evaporative coolers	Whitley, William	31451 E 167th Ave	303-961-8859	BOX	Discussed changes in blending and % of RO water	
43	8/5/11	Pleased with water quality	Leonard, Travis	16720 Kenuil Ct.	303-655-3744	RHF		Email to T. Krayenhagen
44	11/7/11	Water smells musty when first turned on	Snider, Bev	16675 Stroilway	303-467-5882	Box	Checking with Engineer	Flushed Fire Hydrant near house; smelled like chlorine; called Bev to let her know we had flushed to see if that helped
45	11/25/11	Brown water	Moore, Ken	16480 Timber Cove	720-685-7167	BOX	Sent email to Terry K.	

46	2/21/12	high water usage	Neff, Linda	28580 E. 160th Pl	303-654-9860	GN	asked Mike to verify meter pit isn't full of water	2/21/12: Mike went onsite and confirmed the meter pit was dry.
47	3/26/12	Flushed All Hydrants	REC,Inc.	All three subdivisions		BOX,GN.RHF	Will provide Separate Memo	
48	06/20/12	Low PSI and yucky water in filters	Greer, Sherry	16385 Jalna Ct	303-637-9200	RHF	Increased pressure at Rocking Horse Farms Pump station from 60 to 65 psi.	
49	07/20/12	Brown Water	Keith	16685 Keniul Ct	303-915-0918	RHF	Flushed Hydrant next to house	
50	09/15/12	Brown Water	Ted Obrecht	16460 Tree Haven St	303-659-1914	BOX	Flushed Hydrant next to house	
51	01/24/13	Brown Water/odor	Terry Snyder	16675 Stroilway	303-655-1292	BOX	previous day had a water leak/	
52	04/08/13	Low Water Pressure	Debra Brown	16685 Keniul Ct	303-915-0918	RHF	Operator checked outside facuet with pressure gauge and it was showing 70 psi. Opeartor called and left homeowner a message of his findings.	
53	04/18/13	Low Water Pressure/Brown Water	Several Customers			GRN	Large Fire in the area and Fire Department was pulling water from hydrants creating low and high pressure spikes along with brown water from stirring up the lines. Operator checked out and found no issues upon arrival	
54	05/29/13	Low Water Pressure	Tony	30265 E. 166th Ave	720-352-0290	RHF	Spoke with the Tony and advised him I would increase the pressure at the pump station a couple pounds. Also advised him to double check his pressure reducing valve setpoint.	
55	06/11/13	Low Water Pressure	John and several others	30061 East 163rd Ave.	303-655-8614	RHF	Spoke with the John and advised him we were looking into the issue.	
56	June 19-23	Low Water Pressure	several residents	Rocking Horse Farms		RHF	Working with Timberline on low pressure issues	
57	06/25/13	Brown/smelly Water	Greg Mott	16770 Kenosha Ct		RHF	Flushed Hydrant next to house	
58	07/24/13	Blue/Pink Water	Joe Martinez	16450 Timber Cove St.	303-591-5726	BE	Blue marks are due to leaking facuet and toliet that he has repaired and will keep an eye on	
59	July 25 - August 12	Low Water Pressure	several residents	Rocking Horse Farms		RHF	Working with Timberline on low pressure issues	