



# COLORADO

Department of Public  
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

June 11, 2015

Kip Egalite, General Manager  
Lindsay Precast  
P.O. Box 5440  
Colorado Springs, CO 80931

Subject: Lindsay Precast, Septic Tank - Acceptance  
For Use in Colorado On-site Wastewater Treatment Systems

Dear Mr. Egalite:

Pursuant to section 43.13 of the On-site Wastewater Treatment System Regulation 5 CCR 1002-43 (Regulation 43), the Water Quality Control Division (Division) has reviewed drawings and specifications received May 27, 2015, for the following septic tanks:

- 1000 Gallon, Double Compartment
- 1250 Gallon, Double Compartment
- 1500 Gallon , Double Compartment
- 2250 Gallon, Double Compartment

The Division finds the tank design to be consistent with the criteria of section 43.9 of Regulation 43. The Division also provides this acceptance of the tank(s) referenced above as meeting these criteria and acceptable for use in Colorado.

The materials reviewed included evidence that Lindsay Precast is a manufacturer that participates in the Plant Certification Program of the National Precast Concrete Association (NPCA) so watertightness testing is not required pursuant to section 43.13(G)(2). However, note that a valid certificate from NPCA must be submitted to the Division on an annual basis.

This acceptance does not constitute an endorsement of this product. As individual local public health agency regulations may be more stringent than Regulation 43, the Division cannot ensure the acceptance of a septic tank within any given jurisdiction.

If you have any questions regarding the Division's review or findings, please contact me at (303) 692-2366 or [chuck.cousino@state.co.us](mailto:chuck.cousino@state.co.us).

Sincerely,

Charles J. Cousino, REHS  
On-site Wastewater Treatment System Coordinator  
Engineering Section  
Water Quality Control Division  
Colorado Department of Public Health and Environment

cc: Files

