Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
Jan 26 – Feb 20th

1/26/15: Regular checks and readings. Flushed the fire hydrant on Kenuil Ct. Jeff completed quarterly operations review with John, Lisa and Brad.

1/28/15: Regular checks and readings.

1/30/15: Regular checks and readings. Mixed anti-scalent. CIP RO.

2/2/15: Regular checks and readings. Collected and delivered TDS samples.

2/4/15: Regular checks and readings.

2/6/15: Regular checks and readings. Completed a locate at 29150 E 160th Ct for water line relocation. Completed a locate at 16540 Iredell St for a new septic system.

2/9/15: Regular checks and readings. Collected and delivered monthly bacti samples.

2/11/15: Regular checks and readings. Collected and delivered concentration pond samples.

2/13/15: Regular checks and readings. Repaired leaking line to valve at Greatrock North pump house.

2/16/15: Regular checks and readings. Picked up and delivered metal detector and portable light.

2/18/15: Regular checks and readings. Cleaned up pump at Boxelder. Jeff joined monthly consultant conference call with Jennifer, Lisa and Brad.

2/20/15: Regular checks and readings.

Jan 23rd to Feb 18th

RO Run Time Hrs	140.10 hrs
RO Concentrate Flow – 1 pond	277,398 gallons

2/2/15

Monthly Testing	TDS(mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness(mg/L)
BE	350	25.6	4.7	83.4
RHF	394	34.9	6.5	113.8
GRN	383	32.0	6.0	104.6