TZA Water Engineers
a Lamp Rynearson Company

12596 W. Bayaud Ave., Ste. 330
Lakewood, Colorado 80228
303-971-0030
tza4water.com

February 16, 2015

Mr. Matt Hannan, Service Manager (via e-mail: mhannan@strgroup.com)
Water Technology Group
6345 Downing Street
Denver, CO 80216

Re: Box Elder Creek Ranch Pump Station Warranty Inspection
Greatrock North Water and Sanitation District
TZA Project No. 0414018.01

Dear Mr. Hannan:

Thank you for your participation of the 11-month warranty inspection at the Box Elder Creek Ranch Pump Station. The Greatrock North Water and Sanitation District (District) appreciates your attentiveness to our needs and the continued success of this project.

As noted at the inspection, there was one item of concern:

1) At some undetermined time since start-up, it appears the mechanical seal leaked on Pump No. 1 (northern-most pump). The seal is not currently leaking and does not require any service at this time, but its condition is noted in regard to the warranty period.

The District does desire a quotation for a spare mechanical seal and O-ring to be stored on-site for the e-SV pumps (Catalog Number 46SV22GD30). This quotation can be e-mailed to me at bsimons@tza4water.com.

Again, thank you for your participation in the warranty inspection. Should you have any questions, please contact me at 303-971-0030, Extension 4.

Sincerely,

TZA WATER ENGINEERS

Bradley A. Simons, P.E.
District Engineer

cc: Lisa Johnson, District Manager (via e-mail)