Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
January 29th – February 24th

1/29/14: Regular checks and readings.

1/31/14: Regular checks and readings.

2/3/14: Regular checks and readings.

2/5/14: Regular checks and readings.

2/7/14: Regular checks and readings.

2/10/14: Regular checks and readings. Mixed RO antiscalent. Completed a water line inspection at 16250 Queensview St.

2/12/14: Regular checks and readings. Checked the fuel and oil levels in all generators. Cleaned the fresh air filters on the VFD control panels.

2/14/14: Regular checks and readings.

2/17/14: Regular checks and readings.

2/19/14: Regular checks and readings.

2/21/14: Regular checks and readings.

2/24/14: Regular checks and readings.

Pond levels are below depth markers.

January 29th – February 24th

RO Run Time Hrs	91.1 hrs.
RO Concentrate Flow – 2 ponds	180,378 gallons

Completed Work Order List Report

2/24/2014

Completed	Equipment Number	Task	Priority	WO#	Type
2/12/2014	RHF Generator	Ck Oil Check Oil Level(069)	5	277.01	Scheduled
2/12/2014	RHF Generator	Ck Fuel Check Fuel Level	5	276.01	Scheduled
2/12/2014	GN Generator	Ck Oil Check Oil Level(069)	5	274.01	Scheduled
2/12/2014	GN Generator	Ck Fuel Check Fuel Level	5	273.01	Scheduled
2/12/2014	BOX Generator	Ck Oil Check Oil Level(069)	5	272.01	Scheduled
2/12/2014	BOX Generator	Ck Fuel Check Fuel Level	5	271.01	Scheduled
2/12/2014	BOX BP3 VFD	Clean Eqp Clean Equipment	5	270.01	Scheduled
2/12/2014	BOX BP2 VFD	Clean Eqp Clean Equipment	5	269.01	Scheduled
2/12/2014	BOX BP1 VFD	Clean Eqp Clean Equipment	5	268.01	Scheduled