Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
March 27th - April 22nd

3/27/13: Regular checks and readings. Pond levels: North Pond = 71/4"; South Pond = 71/4".

3/29/13: Regular checks and readings. Assisted Kelly with Timberline Electric installing new transducer in the south concentration pond.

4/1/13: Regular checks and readings.

4/3/13: Regular checks and readings. Both pond levels = 7".

4/5/13: Regular checks and readings. Greased and cleaned pump motors at Greatrock.

4/8/13: Regular checks and readings. Responded to low pressure complaint at 16685 Kenvil St. It was 70psi. Mixed RO antiscalent.

4/10/13: Regular checks and readings.

4/12/13: Regular checks and readings.

4/15/13: Regular checks and readings.

4/17/13: Regular checks and readings.

4/18/13: Additional visit to check system after home fire and mass hydrant use. All tank levels were in normal range.

4/19/13: Regular checks and readings.

4/22/13: Regular checks and readings.

March 25 to April 22, 2013

RO Run Time Hrs	128 hrs.
RO Concentrate Flow – 2 ponds	253, 540 gallons

CONCENTRATE PONDS:

North Pond 4-10-13

South Pond 4-10-13

Completed Work Order List Report

4/22/2013

Completed	Equipment Number	Task	Priority	WO#	Type
4/5/2013	GN Booster pump 1	grease grease pump motor	1	176.01	Scheduled
4/5/2013	GN Booster pump 2	grease grease pump motor	1	177.01	Scheduled
4/5/2013	GN Booster Pump 3	grease grease pump motor	1	178.01	Scheduled
3/25/2013	BOX RO system	CIP Clean in place	1	164.01	Scheduled