

Received Date _____
Received By _____

Permit Number _____



MID ROOF INSPECTION AFFIDAVIT TOWN OF ESTES PARK DEPT. OF BUILDING SAFETY

170 MacGregor Ave., P.O. Box 1200
Estes Park, Colorado 80517
(970) 577-3722
Fax (970) 586-0249
www.estesnet.com

_____ The Department has pre approved the roofing installation to be completed without a mid roof inspection, due to impending inclement weather or work being scheduled to be done on a weekend.

_____ The contractor failed to obtain required mid roof inspection as required by sec. 109.1.5.

The contractor shall complete this Department letter and leave it with the inspection card at the jobsite.

**I verify that the mid roof installation at (address) _____
was performed in accordance with Chapter 9 of the 2003 IRC and Amendments / Chapter 15 of the 2003 IBC
and the manufacturers' installation specifications, including but not limited to the following:**

1. All roof areas less than 4 / 12 pitch have been protected by an ice water shield.
2. Shingles have been fastened per manufacturer instruction (on packages) for high wind area.
3. Type of fasteners used (specify) _____
4. The underlayment was inspected and found to be in an acceptable condition or has been replaced.
5. The flashing was inspected and found to be in an acceptable condition or was replaced.
6. Ventilation has been provided; minimum 1 sq. ft. per 150 sq. ft. attic space.

With my signature I verify the installation meets Building Code and manufacturer's specifications and I release the Town of Estes Park from any liability.

Town of Estes Park Business License Number _____

Company name _____

Signed _____

After installation is complete, call for a final inspection by the Building Department.
The permit and inspection record card are required to be available at the time of the final inspection.
Provide a ladder for access to inspect all areas of the new roof.