Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
September 22nd – October 24th

9/22/14: Regular checks and readings.

9/24/14: Regular checks and readings. Worked on the RO low pressure switch. Collected and delivered monthly samples and annual lead and copper.

9/26/14: Regular checks and readings. .

9/29/14: Regular checks and readings.

10/1/14: Regular checks and readings. Collected and delivered samples for alluvial wells and ponds.

10/3/14: Regular checks and readings.

10/6/14: Regular checks and readings.

10/8/14: Regular checks and readings.

10/10/14: Regular checks and readings.

10/13/14: Regular checks and readings. Onsite with Rocky Mountain Generator. Greatrock North - the generator was in alarm. Not audible, but the LED toward the bottom of the panel was lit. The Rep acknowledged the alarm (unknown - possibly priming he guessed), reset it and manually started the generator. Then there was no problem. Completed a test under load by running one of the well pumps. All else checked out okay.

Rocking Horse Farms - John was there removing the key to the doors (in lockbox) to make copies. The generator maintenance completed with no problems. Recommended replacing the battery (2010) every four years - probably next cycle.

Box Elder - Maintenance completed with no problems. The clock on the Cutler-Hammer control was off by a few minutes so he reset the clock.

10/15/14: Regular checks and readings.

10/17/14: Regular checks and readings. Installed a lock box on the alluvial well shed.

10/20/14: Regular checks and readings. Completed potholing, with Redman Potholing, on six addresses in Rocking Horse Farms. We were able to exercise five out of the six due to the sixth one being a vacant lot and not being able to turn on the water. Collected and delivered Total Coliform samples.

10/22/14: Regular checks and readings. Flushed the hydrant on Kenuil Ct.

10/24/14: Regular checks and readings.

September 22nd – October 24th

RO Run Time Hrs	193.5 hrs
RO Concentrate Flow – 2 ponds	383,130 gallons