Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
September 25th – October 24th

9/25/13: Regular checks and readings. Cleaned the VFDs at Boxelder. Collected and delivered monthly samples.

9/27/13: Regular checks and readings. Reset pump #1 at Rocking Horse Farms due to overvoltage.

9/30/13: Regular checks and readings. Collected and delivered TDS and alkalinity samples.

10/2/13: Regular checks and readings.

10/4/13: Regular checks and readings. Reset Rocking Horse Farms booster pump #2.

10/7/13: Regular checks and readings.

10/9/13: Regular checks and readings. Distributed new valve keys, hydrant wrenches, pressure gauges and diffusers at the 3 pump stations.

10/11/13: Regular checks and readings. Flushed the hydrant on Kenuil Ct. Removed and cleaned pond aerator. Exercised the valves at Rocking Horse Farms. Covered all of the vents on the buildings for winter. Cleaned all 3 pump stations.

10/14/13: Regular checks and readings. The pressure reducer on pump #1 at Greatrock North was not working. Turned off pump #1 and pump #2 holding pressure of 65psi.

10/16/13: Regular checks and readings.

10/18/13: Regular checks and readings.

10/21/13: Regular checks and readings. Filled the chlorine tank.

10/23/13: Regular checks and readings. Set trash out for pickup.

10/24/13: Regular checks and readings. Hung distribution system maps on the walls of each pump station. Fed rodents.

Pond levels are below depth markers.

August 26th – September 23rd

RO Run Time Hrs	7.4 hrs.
RO Concentrate Flow – 2 ponds	14,652 gallons