Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
August 26th – September 23rd

8/26/13: Regular checks and readings.

8/28/13: Regular checks and readings. Completed plant tour with Board Members. Responded to a low pressure complaint at 3002 E 160th.

8/30/13: Regular checks and readings. Filled the chlorine tank.

9/2/13: Regular checks and readings.

9/4/13: Regular checks and readings.

9/6/13: Regular checks and readings. Attempted to shut off the water to repair curb stop at Rocking Horse Farms. Responded to a water complaint at 29957 166th Pl and flushed the hydrant for 10 minutes.

9/9/13: Regular checks and readings. Replaced the pump tube on Boxelder's chlorine pump. The pond levels are both below the gauge sticks.

9/11/13: Regular checks and readings. Cleaned the chlorine injector.

9/13/13: Regular checks and readings.

9/16/13: Regular checks and readings. Pond levels: north = 2"; south = 3".

9/18/13: Regular checks and readings.

9/20/13: Regular checks and readings. Reboot SCADA.

August 26th – September 23rd

RO Run Time Hrs	14 hrs.
RO Concentrate Flow – 2 ponds	27,720 gallons

CONCENTRATE PONDS:

North Pond 9-9-13

South Pond 9-9-13

North Pond 9-16-13

South Pond 8-7-13