Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
August 26th – September 19th

8/26/14: Regular checks and readings. Collected and delivered the MPA sample.

8/27/14: Regular checks and readings.

8/29/14: Regular checks and readings. The control panel did not have power, upon arrival; due to the UPS system inside the panel was restarted, indicating battery failure. Battery was replaced and UPS was back up and running.

9/1/14: Regular checks and readings.

9/3/14: Regular checks and readings. Check flow meter by-pass valves at Greatrock and Rocking Horse Farms were all closed. Cleaned the chlorine injector.

9/5/14: Regular checks and readings.

9/8/14: Regular checks and readings. Reset overvoltage fault on both booster pumps at Rocking Horse Farms.

9/10/14: Regular checks and readings. Checked the pond aerator.

9/12/14: Regular checks and readings.

9/15/14: Regular checks and readings.

9/17/14: Regular checks and readings. Completed a water service line inspection at 31329 E 164th Ave.

9/19/14: Regular checks and readings. ISI West on site to rebuild PRV at GRN on booster pump #1. ISI West also took inventory of all PRV's they rebuilt.

RO unit started shutting down on low inlet pressure. TLECC out to check but RO unit started running fine. A week later RO started shutting down on low inlet pressure again. TLECC is currently scheduled to be back on site 9/24/14 to test and inspect pressure sensor.

August 25th – September 19th

RO Run Time Hrs	35.70 hrs
RO Concentrate Flow – 2 ponds	64,260 gallons