Ramey Environmental Compliance, Inc.
Management and Operation Solutions for
Water and Wastewater Treatment
303-833-5505

PO Box 99, Firestone, Colorado 80520
email: contact.us@RECinc.net
www.RECinc.net

Greatrock North W & S District
Monthly Activities
July 28th – August 22nd

7/28/14: Regular checks and readings. Look over locates for 28567 E 163rd Place, lot #45.

7/29/14: Regular checks and readings. Meet with ISI West to fix the leak on pump #1 PRV valve at Greatrock.

8/1/14: Regular checks and readings.

8/4/14: Regular checks and readings. Exercised valves at Rocking Horse, Greatrock North and Boxelder. Met with John Wyckoff for locates at lot #45.

8/6/14: Regular checks and readings. Picked up and delivered "Hydrant out of Service" signs. Placed a "Hydrant out of Service" sign at 28875 E 160th Pl. Exercised the valves at Boxelder.

8/8/14: Regular checks and readings. Cleaned the chlorine injector. Contractor onsite to assess damage to the roof at Greatrock North.

8/11/14: Regular checks and readings. Completed the generator inspections.

8/12/14: Regular checks and readings. Onsite with Water Technology Group (WTG) to troubleshoot the two booster pump operation at RHF.

8/14/14: Regular checks and readings. Onsite with WTG for vibration testing at Boxelder. Onsite with Water Technology Group to troubleshoot Rocking Horse Farms booster pumps.

8/19/14: Regular checks and readings. Collected and delivered monthly samples.

8/20/14: Regular checks and readings.

8/22/14: Regular checks and readings.

July 28th – August 22nd

RO Run Time Hrs	129.70 hrs
RO Concentrate Flow – 2 ponds	256,806 gallons