

Received Date:	Permit Number:
Received By:	Address:
 TOWN OF ESTES PARK www.estes.org 970-577-3726 PO Box 1200 170 McGregor Ave Estes Park, CO 80517	STRUCTURAL EXTERIOR WALL AND ROOF SHEATHING (NOT ENGINEERED) AFFIDAVIT OF COMPLIANCE Town of Estes Park Division of Building Safety

The following conditions must be met before submitting an Affidavit:

- The contractor shall be pre-approved by the Chief Building Official
- The work shall be authorized by the appropriate permit
- The work shall be associated with an approved system
- The affidavit shall be on a form provided by the CBO

Check the statements that apply:

- The Division has pre-approved the wall / roof sheathing installation to be completed without Division inspection.
- The installing contractor shall complete and sign this affidavit.
- The affidavit shall be left in the permit pack at the jobsite.
- The work and conditions described on the approved plan matches the field installation.
- Sheathing has been attached to required backing at edges and joints of sheathing.
- Vertical joints break and are nailed on minimum 1 ½” thick backing.
- Fastener type and nailing pattern are as per the approved plan OR as per Tables R602.3 (1) thru (4).
- Fastener heads/crowns are flush to sheathing, are not overdriven and are within 3/8” of edge of panels.
- Roof sheathing is properly oriented and continuous over two or more spans.
- Nails for attaching roof panel sheathing to intermediate supports are spaced 6” O.C. for a minimum 48” distance from ridge, eaves and gable end walls; and 4” O.C. to gable end walls.
- (OPTIONAL> Photos of the ongoing installation have been provided.

With my signature I verify the structural sheathing installation was performed in accordance with the manufacturers' installation specifications, Chapter 6 of the 2009 IRC or Chapter 23 of the 2009 IBC and I release the Town of Estes Park from all liability*.

Contractor Signature:	Date:
Company Name:	Town Business License Number:

*A Contractors' Affidavit of Compliance shall not exempt work from corrections if the building official determines the work does not comply with the provisions of this code.