ARRIBA TOWN OF 2014 Drinking Water Quality Report
For Calendar Year 2013

Public Water System ID: CO0137001

Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.

We are pleased to present to you this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. Please contact PATRICK PARKER at 303-838-7299 with any questions about the Drinking Consumer Confidence Rule (CCR) or for public participation opportunities that may affect the water quality.

General Information

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting http://water.epa.gov/drink/contaminants.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and microbiological contaminants call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

•**Microbial contaminants:** viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
•**Inorganic contaminants:** salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
•**Pesticides and herbicides:** may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
•**Radioactive contaminants:** can be naturally occurring or be the result of oil and gas production and mining activities.
•**Organic chemical contaminants:** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems (especially for pregnant women and young children). It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. If you are concerned about lead in your water, you may wish to have your water tested. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at http://www.epa.gov/safewater/lead.

Source Water Assessment and Protection (SWAP)

The Colorado Department of Public Health and Environment has provided us with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit http://wqcdcompliance.com/ccr. The report is located under "Source Water Assessment Reports", and then "Assessment Report by County". Select LINCOLN County and find 137001; ARRIBA TOWN OF or by contacting PATRICK PARKER at 303-838-7299. The Source Water Assessment Report provides a screening-level evaluation of potential contamination that ***could*** occur. It ***does not*** mean that the contamination ***has or will*** occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Potential sources of contamination in our source water area are listed on the next page.

Please contact us to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Consumer Confidence Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.

Our Water Sources

Source	Source Type	Water Type	Potential Source(s) of Contamination
NORTH WELL IN TOWN	WL	GW	Above ground/underground leaking storage tank sites. Land use or land cover types of potential contamination include: Commercial, industrial transportation, row crops, fallow and small grains, leaking septic systems and road miles
SOUTH WELL IN TOWN	WL	GW	Above ground/underground leaking storage tank sites. Land use or land cover types of potential contamination include: Commercial, industrial transportation, row crops, fallow and small grains, leaking septic systems and road miles
NORTH WELL OUT OF TOWN	WL	GW	Above ground/underground leaking storage tank sites. Land use or land cover types of potential contamination include: Commercial, industrial transportation, row crops, fallow and small grains, leaking septic systems and road miles
SOUTH WELL OUT OF TOWN	WL	GW	Above ground/underground leaking storage tank sites. Land use or land cover types of potential contamination include: Commercial, industrial transportation, row crops, fallow and small grains, leaking septic systems and road miles

Terms and Abbreviations

- **Maximum Contaminant Level (MCL)** − The highest level of a contaminant allowed in drinking water.
- **Treatment Technique (TT)** − A required process intended to reduce the level of a contaminant in drinking water.
- **Action Level (AL)** − The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.
- **Maximum Residual Disinfectant Level (MRDL)** − The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Contaminant Level Goal (MCLG)** − The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** − The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Violation (No Abbreviation)** − Failure to meet a Colorado Primary Drinking Water Regulation.
- **Formal Enforcement Action (No Abbreviation)** − Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.
- **Variance and Exemptions (V/E)** − Department permission not to meet a MCL or treatment technique under certain conditions.
- **Gross Alpha (No Abbreviation)** − Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.
- **Picocuries per liter (pCi/L)** − Measure of the radioactivity in water.
- **Nephelometric Turbidity Unit (NTU)** − Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.

- **Compliance Value (No Abbreviation)** – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90th Percentile, Running Annual Average (RAA) and Locational Running Annual Average (LRAA).
- **Average (x-bar)** − Typical value.
- **Range (R)** − Lowest value to the highest value.
- **Sample Size (n)** − Number or count of values (i.e. number of water samples collected).
- **Parts per million = Milligrams per liter (ppm = mg/L)** − One part per million corresponds to one minute in two years or a single penny in $10,000.
- **Parts per billion = Micrograms per liter (ppb = ug/L)** − One part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.
- **Parts per trillion = Nanograms per liter (ppt = ng/L)** − One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in $10,000,000,000.
- **Parts per quadrillion = Picograms per liter (ppq = pg/L)** − One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in $10,000,000,000,000.
- **Not Applicable (N/A)** – Does not apply or not available.

Detected Contaminants

ARRIBA TOWN OF routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2013 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report.

Note: Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section then no contaminants were detected in the last round of monitoring.

Lead and Copper Sampled in the Distribution System								
Contaminant Name	**Time Period**	**90th Percentile**	**Sample Size**	**Unit of Measure**	**90th Percentile AL**	**Sample Sites Above AL**	**90th Percentile AL Exceedance**	**Typical Sources**
Copper	09/28/2011 to 09/28/2011	0.21	5	ppm	1.3		No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	09/28/2011 to 09/28/2011	2	5	ppb	15		No	Corrosion of household plumbing systems; Erosion of natural deposits

All Synthetic Organic Chemicals (SOC's) were tested for in 2013. All SOC chemicals were below detectable limit (BDL).

Disinfection Byproducts Sampled in the Distribution System										
Name	**Year**	**Average**	**Range Low – High**	**Sample Size**	**Unit of Measure**	**MCL**	**MCLG**	**Highest Compliance Value**	**MCL Violation**	**Typical Sources**
Total Haloacetic Acids (HAA5)	2011	1.89	1.89 to 1.89	1	ppb	60	N/A		No	Byproduct of drinking water disinfection
Total Trihalome thanes (TTHM)	2011	9.7	9.7 to 9.7	1	ppb	80	N/A		No	Byproduct of drinking water disinfection

Radionuclides Sampled at the Entry Point to the Distribution System									
Contaminant Name	**Year**	**Average**	**Range Low – High**	**Sample Size**	**Unit of Measure**	**MCL**	**MCLG**	**MCL Violation**	**Typical Sources**
Gross Alpha	2013	8.8	8.8 to 8.8	1	pCi/L	15	0	No	Erosion of natural deposits
Combined Uranium	2013	7.7	7.7 to 7.7	1	ppb	30	0	No	Erosion of natural deposits

Inorganic Contaminants Sampled at the Entry Point to the Distribution System									
Contaminant Name	**Year**	**Average**	**Range Low – High**	**Sample Size**	**Unit of Measure**	**MCL**	**MCLG**	**MCL Violation**	**Typical Sources**
Arsenic	2013	4	4 to 4	1	ppb	10	0	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	2013	0.1	0.1 to 0.1	1	ppm	2	2	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	2013	2	2 to 2	1	ppb	100	100	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride	2013	0.4	0.4 to 0.4	1	ppm	4	4	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and

Inorganic Contaminants Sampled at the Entry Point to the Distribution System									
Contaminant Name	**Year**	**Average**	**Range Low – High**	**Sample Size**	**Unit of Measure**	**MCL**	**MCLG**	**MCL Violation**	**Typical Sources**
									aluminum factories
Nitrate	2013	8.05	7.3 to 8.6	4	ppm	10	10	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	2013	7	7 to 7	1	ppb	50	50	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Nitrate: *Nitrate in drinking water at levels above 10 ppm* is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.									

Violations, Significant Deficiencies, and Formal Enforcement Actions

No Violations or Formal Enforcement Actions