



COLORADO

Department of Public Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

April 21, 2015

Derrick Eggleston, President
Valley Precast Inc.
28005 CR 317
P.O. Box 925
Buena Vista, CO 81211

Subject: Valley Precast Septic Tank Submittal- Acceptance Revision
For Use in Colorado On-site Wastewater Treatment Systems

Dear Mr. Eggleston:

Pursuant to section 43.13 of the On-site Wastewater Treatment System Regulation 5 CCR 1002-43 (Regulation 43), the Water Quality Control Division (Division) has reviewed drawings and specifications received May 19, 2014, June 18, 2014, and April 3, 2015, for the following septic tanks:

Models:

- 500T, 500T-2CP
- 1000M-2CP, 1000T-2CP, 1000T-1CP, 1000G-2CP, 1000G-1CP
- 1250M-2CP, 1250T-2CP, 1250T-1CP, 1250G-2CP
- 1500M-2CP, 1500T-2CP, 1500T-1CP, 1500G-2CP, 1500G-1CP
- 2000T-2CP, 2000T-1CP, 2000G-1CP, 2000G-2CP
- 1000T-3CP (1500 gal. vol.), 1500G-3CP (2026 gal. vol.), 1500T-3CP (2026 gal. vol.)

Nomenclature: Number = Effective volume (unless otherwise noted); “M” = Mid-seam; T” = Top-seam; “G” = Seamless tank; 1CP = Single compartment; 2CP = Double compartment; 3 CP = Triple compartment.

Notes:

- All single compartment tanks must be used in series with additional tanks so as to comply with all requirements of section 43.9(B)(4)(a) through (i) of Regulation 43.
- Top-seam tanks with a volume of 1000, 1250, 1500 and 2000 gallons can be special ordered from the manufacturer with a H-20 load rating, or can be manufactured to provide for a deep bury up to 8’ in depth. The design of these tanks have also been granted acceptance by the Division.

The Division finds the tank designs to be consistent with the criteria of section 43.9 of Regulation 43. The Division also provides this acceptance of the tanks referenced above as meeting these criteria and acceptable for use in Colorado.

Note: Pursuant to section 43.13(G)(2), at least five percent of tanks must be tested for watertightness at the manufacturing facility. A summary of testing results must be submitted to the Division on an annual basis. The testing results submittal form is available on the Division website.

This acceptance does not constitute an endorsement of this product. As individual local public health agency regulations may be more stringent than Regulation 43, the Division cannot ensure the acceptance of a septic tank within any given jurisdiction.



*Derrick Eggleston, Valley Precast, Inc.
Septic Tank Acceptance*

*April 21, 2015
Page 2 of 2*

If you have any questions regarding the Division's review or findings, please contact me at (303) 692-2366 or chuck.cousino@state.co.us.

Sincerely,

Charles J. Cousino, REHS
On-site Wastewater Treatment System Coordinator
Engineering Section
Water Quality Control Division
Colorado Department of Public Health and Environment

cc: Files