



COLORADO

Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

May 26, 2015

Mike Vaughn, Manager
Vaughn Concrete Products, Inc.
12650 Tucson Street
Henderson, CO 80640

Subject: Precast Concrete Septic Tank - Acceptance
For Use in Colorado On-site Wastewater Treatment Systems

Dear Mr. Vaughn:

Pursuant to section 43.13 of the On-site Wastewater Treatment System Regulation 5 CCR 1002-43 (Regulation 43), the Water Quality Control Division (Division) has reviewed the revised drawings and specifications received May 14, 2015 for the following septic tank(s):

- Model: 1000 Gallon
- Model: 1250 Gallon
- Model: 1500 Gallon
- Models: 2000, 2500, 3000, 3500 and 4000 Gallon

The Division finds the tank design to be consistent with the criteria of section 43.9 of Regulation 43. The Division also provides this acceptance of the tank(s) referenced above as meeting these criteria and acceptable for use in Colorado.

The materials reviewed included evidence that the above noted plant is certified by the National Precast Concrete Association (NPCA) so watertightness testing is not required pursuant to section 43.13(G)(2). However, a current NPCA certification should be submitted to the Division by February 15 of each calendar year.

This acceptance does not constitute an endorsement of this product. As individual local public health agency regulations may be more stringent than Regulation 43, the Division cannot ensure the acceptance of a septic tank within any given jurisdiction.

If you have any questions regarding the Division's review or findings, please contact me at (303) 692-2366 or chuck.cousino@state.co.us.

Sincerely,

Charles J. Cousino, REHS
On-site Wastewater Treatment System Coordinator
Engineering Section
Water Quality Control Division
Colorado Department of Public Health and Environment

cc: Files

