

CDPS GENERAL PERMIT
FOR NON-CONTACT COOLING WATER
AUTHORIZATION TO DISCHARGE UNDER THE
COLORADO DISCHARGE PERMIT SYSTEM

In compliance with the provisions of the Colorado Water Quality Control Act (25-8-101 et seq., CRS, 1973 as amended), facilities discharging non-contact cooling water are authorized to discharge approved sources from authorized locations throughout the State of Colorado to land and to specified waters of the State. Such discharges shall be in accordance with conditions of this permit.

The applicant may demand an adjudicatory hearing within thirty (30) days of the issuance of the final permit determination, per the Colorado Discharge Permit System Regulations, Regulation No. 61 (5 CCR 1002-61). Should the applicant choose to contest any of the effluent limitations, monitoring requirements or other conditions contained herein, the applicant must comply with Section 24-4-104 CRS and the Colorado Discharge Permit System Regulations. Failure to contest any such effluent limitation, monitoring requirement, or other condition, constitutes consent to the condition by the Applicant.

This permit specifically authorizes the facility listed on page 1 of this permit to discharge process generated wastewaters, as of the date stated below, in accordance with the permit requirements and conditions set forth in Parts I and II hereof. All discharges authorized herein shall be consistent with the terms and conditions of this permit.

This permit and the authorization to discharge shall expire at midnight, **June 30, 2013**

Issued and Signed this **30th** day of **May, 2008**

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT



Janet Kieler, Permits Section Manager
Water Quality Control Division

ISSUED AND SIGNED: MAY 30, 2008

EFFECTIVE DATE: JULY 1, 2008

TABLE OF CONTENTS

PART I 3

A. COVERAGE UNDER THIS PERMIT 3

B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS 4

 1. Effluent Limitations - Steam Power Generating Facilities for Distribution and Sale of Electricity 4

 2. Effluent Limitations - Other Industries/Facilities 6

 3. Compliance Schedules 6

 4. WET Testing 6

C. DEFINITIONS OF TERMS 9

D. GENERAL MONITORING, SAMPLING, AND REPORTING REQUIREMENTS 10

 1. Routine Reporting of Data 10

 2. Reporting - Stormwater Annual Report 11

 3. Representative Sampling 11

 4. Analytical and Sampling Methods for Monitoring 11

 5. Records 12

 6. Flow Measuring Device 12

 7. Signatory and Certification Requirements 12

PART II 14

A. NOTIFICATION REQUIREMENTS 14

 1. Notification to Parties 14

 2. Change in Discharge 14

 3. Special Notifications - Definitions 14

 4. Noncompliance Notification 15

 5. Other Notification Requirements 15

 6. Bypass Notification 16

 7. Upsets 16

 8. Discharge Point 16

 9. Proper Operation and Maintenance 16

 10. Minimization of Adverse Impact 17

 11. Removed Substances 17

 12. Submission of Incorrect or Incomplete Information 17

 13. Bypass 17

 14. Reduction, Loss, or Failure of Treatment Facility 17

B. RESPONSIBILITIES 18

 1. Inspections and Right to Entry 18

 2. Duty to Provide Information 18

 3. Transfer of Ownership or Control 18

 4. Availability of Reports 18

 5. Modification, Suspension, Revocation, or Termination of Permits By the Division 19

 6. Oil and Hazardous Substance Liability 20

 7. State Laws 20

 8. Permit Violations 21

 9. Property Rights 21

 10. Severability 21

 11. Renewal Application 21

 12. Confidentiality 21

 13. Fees 21

 14. Duration of Permit 21

 15. Section 307 Toxics 21

 16. Antibacksliding 21

 17. Effect of Permit Issuance 22

 18. Requiring an Individual CDPS Permit 23

 19. Requesting an Individual CDPS Permit 23

 20. Requesting Coverage Under the General Permit 23

PART I

A. COVERAGE UNDER THIS PERMIT

1. This general permit authorizes discharges of non-contact cooling water (once through and recirculating) and blowdown. Discharges to groundwater may be authorized under this general permit on a case by case basis. Groundwater discharges may be subject to the jurisdiction of the Hazardous Materials Waste Management Division's Solid Waste Unit.

Power generating facilities that distribute or sell electrical power are subject to federal effluent limitation guidelines (ELGs) under 40 CFR Part 423. Other facilities that may be certified under this general are not subject to the federal ELGs.

Discharges may be covered under this permit at the Division's discretion, providing that such wastewater would not require effluent limitations and/or monitoring requirements other than those contained in this permit. Such determinations will be made on a case-by case basis upon review of the permit application and any additional relevant information. If discharge from one or more of the above listed sources require additional limitations and/or monitoring requirements, an individual permit may be required. Multiple discharge points from one facility may be authorized through this permit providing all discharges meet these criteria.

2. In order to apply for certification under this general permit, the owner, operator, and/or authorized agent of the subject facility shall submit by certified mail or hand delivery, the completed General Permit Application for the Discharge of Non-Contact Cooling Water.

If the discharge is to a storm sewer system, ditch, or other manmade conveyance, approval from the owner of the system must be obtained before discharge.

At least 30 days before the anticipated date of discharge, the application in its entirety, shall be submitted to:

Colorado Department of Public Health and Environment
Water Quality Control Division
Permits Section
4300 Cherry Creek Drive South
Denver, CO 80246

The Division shall have up to thirty days after receipt of the above information to request additional data or deny the authorization to discharge under this general permit. Upon receipt of additional information, the Division shall have an additional 30 days to issue or deny authorization to discharge. If the Division determines that a new facility does not fall under the authority of the general permit, then the information received will be processed for an individual permit, and the applicant shall be notified of such a determination. If during the renewal process, the Division determines that a facility no longer qualifies for the general permit, the facility will be allowed to discharge under the general permit until an individual permit is issued.

3. The final limitations to be applied under this permit shall take into consideration the application of the appropriate discharge categories, applicable water quality standards, control regulations, total maximum daily loads, and other regulatory requirements. Potential limitations may include but are not limited to the general limitations as provided in Part I.B below.
4. Authorization to discharge under this general permit shall expire on June 30, 2013. The Division must evaluate this general permit once every five years and must recertify all applicants' authority to discharge under the general permit at such time. Therefore, a permittee desiring continued coverage under the general permit must reapply by November 30, 2012. The Division will determine if the applicant continues to operate under terms of the general permit.
5. No chemicals shall be added to the discharge unless the Division grants specific approval in a certification, letter, or other form of communication. To approve a new chemical, the Division must have the chemical's MSDS sheet. All chemicals must be used and stored in accordance with the manufacturers recommendations and in accordance with any applicable state or federal regulation.
6. There shall be no discharge of solid animal or food waste, vegetative wastes (grass, leaves, manure, garbage, etc), or any floating solids or visible foam, in other than trace amounts.

7. All discharges must comply with the lawful requirements of federal agencies, municipalities, counties, drainage districts and other local agencies regarding any discharges to storm drains systems, conveyances, or other water courses under their jurisdiction. In addition, prior to the discharge the permittee must notify the owner of the system of the date, approximate time, location, and duration of the discharge(s).

B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. Effluent Limitations - Steam Power Generating Facilities for Distribution and Sale of Electricity

a. Once Through Cooling Water - The following limitations and monitoring requirements are for the discharge of once through non-contact cooling water from steam power generating facilities that distribute and sell electricity. Once through cooling water is defined as one or two passes. The federal ELG limitations may be found under 40 CFR Part 423. Note that if once through cooling water is discharged in combination with recirculating water or blowdown, the limits in Part I.B.1.b will apply.

Parameter	Discharge Limitations			Rationale	Monitoring Frequency	Sample Type
	30-day average	7-day average	Daily Maximum			
-----General Permit Requirements-----						
Flow, MGD	Report	NA	Report	Discharge Evaluation	Continuous/ Instantaneous ¹	Recorder /In situ ¹
TSS, mg/l	30	45	NA	State Effluent Limits	Weekly	Grab
Oil and Grease, mg/l	NA	NA	10	State Effluent Limits	Weekly	Visual ²
-----Federal Effluent Limitation Guidelines (ELGs)-----						
TRC mg/l < 25 megawatts > 25 megawatts	- 0.2 NA	- NA NA	- 0.5 0.2	Federal ELG	Weekly	Grab
PCBs	No Detectable Amount			Federal ELG	Annual	Grab
-----Site Specific Limitations-----						
pH, s.u.	NA	NA	6.5 -9.0	Water Quality Standards	Weekly	Grab
Temperature, °C	NA	Various ³ (MWAT)	Report ³ (2 hr max)	Water Quality Standards	Continuous ⁴	Recorder ⁴
TRC, mg/l	0.011	NA	0.019	Water Quality Standards	Weekly	Grab
TDS, mg/l ⁵	Report	NA	Report	Salinity Regulations	Quarterly ⁵	Grab
Total Phosphorus, mg/l ⁶	Report	NA	NA	Control Regulations	Monthly	Grab
Metals, ug/l	Various	NA	Various	Water Quality Standards	Various	Grab
Organics, ug/l	Various	NA	Various	Water Quality Standards	Various	Grab

- 1 - If this is a continuous discharge, a flow meter should be used to record flow on a continuous basis. If this is an intermittent discharge, an instantaneous measurement basis may be used.
- 2 - There shall be no visible sheen. If a visible sheen is observed, a grab sample must be taken and analyzed for oil and grease.
- 3 - The limitation for temperature is based upon the classification of the receiving stream as aquatic life warm or cold, and will be determined on a case by case basis. See Section III.c.3 for more information and for definitions.
- 4 - In order to obtain the proper readings to comply with the MWAT or 2-hour maximum, automated temperature sampling and recording equipment is required.
- 5 - The TDS limitation will normally apply to discharges in the Colorado River Basin. An evaluation of the discharge will take place upon certification, to see if the facility meets the 1 ton/day or 366 tons/year allowable discharge of salt. If the facility does not meet this requirement, the facility will be required to submit a salinity report documenting that achieving this level of discharge is not feasible. See Regulation 61.8(2)(I) for more information. If the limit is based on discharge to the Colorado River Basin the measurement frequency will be quarterly. If the limit is based on agricultural protection, the measurement frequency will be weekly.
- 6 - The phosphorus limitations apply to discharges to the Dillon Reservoir Watershed, Cherry Creek Reservoir Watershed, Chatfield Reservoir Watershed, and the Bear Creek Watershed, as defined in Regulations 71, 72, 73 or 74 respectively. The permittee may be required to obtain a phosphorus allocation from the applicable control regulation authority prior to certification under this general permit.

b. Recirculating Non-Contact Cooling Water and Blowdown, or Combination of Once Through and Recirculating Cooling Water or Blowdown - The following limitations and monitoring requirements are for the discharge of recirculating non-contact cooling water and blowdown, and or discharge in combination with once through cooling water, from steam power generating facilities that distribute and sell electricity. The federal ELG limitations may be found under 40 CFR Part 423.

Parameter	Discharge Limitations			Rationale	Monitoring Frequency	Sample Type
	30-day average	7-day average	Daily Maximum			
-----General Permit Requirements-----						
Flow, MGD	Report	NA	Report	Discharge Evaluation	Continuous/ Instantaneous ¹	Recorder /In situ ¹
TSS, mg/l	30	45	NA	State Effluent Limits	Weekly	Grab
Oil and Grease, mg/l	NA	NA	10	State Effluent Limits	Weekly	Visual ²
-----Federal Effluent Limitation Guidelines (ELGs)-----						
TRC mg/l	0.2	NA	0.5	Federal ELG	Weekly	Grab
PCBs, ug/l	No Detectable Amount			Federal ELG	Annual	Grab
126 Priority Pollutants (except Cr and Zn), ug/l	No Detectable Amount			Federal ELG	Annual	Grab
Chromium, Total, ug/l *	200	NA	200	Federal ELG	Monthly	Grab
Zinc, Total, ug/l	1000	NA	1000	Federal ELG	Monthly	Grab
-----Site Specific Limitations-----						
pH, s.u.	NA	NA	6.5 -9.0	Water Quality Standards	Weekly	Grab
Temperature, °C	NA	Various ³ (MWAT)	Report ³ (2 hr max)	Water Quality Standards	Continuous ⁴	Recorder ⁴
TRC, mg/l	0.011	NA	0.019	Water Quality Standards	Weekly	Grab
TDS, mg/l ⁵	Report	NA	Report	Salinity Regulations	Quarterly ⁵	Grab
Total Phosphorus, mg/l ⁶	Report	NA	NA	Control Regulations	Monthly	Grab
WET, Chronic	NA	NA	Stat Diff and IC25 > 100%	Water Quality Standards	Quarterly	3 Grabs / Test
Hexavalent Chromium, ug/l*	11	NA	16	Water Quality Standards	Monthly	Grab
Trivalent Chromium, ug/l *	Various	NA	Various	Water Quality Standards	Monthly	Grab
Total Chromium *	NA	NA	50	Water Quality Standards	Monthly	Grab
Zinc, ug/l	Various	NA	Various	Water Quality Standards	Monthly	Grab
Metals, ug/l	Various	NA	Various	Water Quality Standards	Various	Grab
Organics, ug/l	Various	NA	Various	Water Quality Standards	Various	Grab

* If the discharge is to a water supply segment, only the total chromium limitation based on the water quality standards will apply, as this is more stringent than the federal ELG.

See footnotes under Part I.B.1.a

2. Effluent Limitations - Other Industries/Facilities

a. Once Through Non-Contact Cooling Water, Recirculating Non-Contact Cooling Water and Blowdown - The limitations and monitoring requirements contained in Table III-3 are for the discharge of once through non-contact cooling water from steam electric power generating facilities that DO NOT distribute and sell electricity, and other industrial facilities. Once through is defined as one or two passes.

Parameter	Discharge Limitations			Rationale	Monitoring Frequency	Sample Type
	30-day average	7-day average	Daily Maximum			
-----General Permit Requirements-----						
Flow, MGD	Report	NA	Report	Discharge Evaluation	Continuous/ Instantaneous ¹	Recorder /In situ ¹
TSS, mg/l	30	45	NA	State Effluent Limits	Weekly	Grab
Oil and Grease, mg/l	NA	NA	10	State Effluent Limits	Weekly	Visual ²
-----Site Specific Limitations-----						
pH, s.u.	NA	NA	6.5 -9.0	Water Quality Standards	Weekly	Grab
TRC, mg/l	0.011	NA	0.019	Water Quality Standards	Weekly	Grab
Temperature, °C	NA	Various ³ (MWAT)	Report ³ (2 hr max)	Water Quality Standards	Continuous ⁴	Recorder ⁴
TRC, mg/l	0.011	NA	0.019	Water Quality Standards	Weekly	Grab
TDS, mg/l ⁵	Report	NA	Report	Salinity Regulations	Quarterly ⁵	Grab
Total Phosphorus, mg/l ⁶	Report	NA	NA	Control Regulations	Monthly	Grab
WET, Chronic *	NA	NA	Stat Diff and IC25 > 100%	Water Quality Standards	Quarterly	3 Grabs / Test
Metals, ug/l	Various	NA	Various	Water Quality Standards	Various	Grab
Organics, ug/l	Various	NA	Various	Water Quality Standards	Various	Grab

* Will normally apply to discharges containing recirculating water and blowdown
See footnotes under Part I.B.1.a

3. Compliance Schedules

Any compliance schedule related requirements will be included in the certifications.

4. WET Testing

a. Acute WET Testing (See also Part I.B.7.c for WET requirements applicable to both chronic and acute WET testing)

1. Testing and Reporting Requirements

Tests shall be done at the frequency listed in Part I.B.1. Test results shall be reported along with the Discharge Monitoring Report (DMR) submitted for the end of the reporting period when the sample was taken. (i.e., WET testing results for the calendar quarter ending March 31 shall be reported with the DMR due April 28, etc.) The results shall be submitted on the Acute Toxicity Test report form, available from the Division. Copies of these reports are to be submitted to the Division along with the DMR.

The permittee shall conduct each acute WET test in general accordance with methods described in Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms EPA/600/4-90/027 or its most current edition, except as modified by the most current Division guidance document entitled Guidelines for Conducting Whole Effluent Toxicity Tests. The permittee shall conduct an acute 48-hour WET test using Ceriodaphnia sp., and an acute 96-hour WET test using fathead minnows. Acute tests will be replacement static tests of a single effluent grab sample.

2. Failure of Test and Division Notification

An acute WET test is failed whenever the LC₅₀, which represents an estimate of the effluent concentration which is lethal to 50% of the test organisms in the time period prescribed by the test, is found to be less than or equal to 100% effluent. The permittee must provide written notification of the failure of a WET test to the Division, along with a statement as to whether the Preliminary Toxicity Incident (PTI)/Toxicity Identification Evaluation (TIE) investigation or accelerated testing is being performed. **Notification must be received by the Division within 14 calendar days of the demonstration of acute WET in the routine required test.** Demonstration for the purposes of Parts I.A.3.b., c., d. and (f) means no later than the last day of the laboratory test.

b. Chronic WET Testing (See also Part I.B.7.c for WET requirements applicable to both chronic and acute WET testing)

1. Testing and Reporting Requirements

Tests shall be done at the frequency listed in Part I.B.1. Test results shall be reported along with the Discharge Monitoring Report (DMR) submitted for the reporting period during which the sample was taken. (i.e., WET testing results for the first calendar quarter ending March 31 shall be reported with the DMR due April 28.) The results shall be submitted on the Chronic Toxicity Test report form, available from the Division. Copies of these reports are to be submitted to the Division along with the DMR.

The permittee shall conduct each chronic WET test in general accordance with methods described in Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, EPA/600/4-89/001 or the most current edition, except as modified by the most current Division guidance document entitled Guidelines for Conducting Whole Effluent Toxicity Tests. The permittee shall conduct such tests using *Ceriodaphnia dubia* and fathead minnows.

2. Failure of Test and Division Notification

A chronic WET test is failed whenever 1) there is a statistically significant difference in lethality between the control and any effluent concentration less than or equal to the instream waste concentration (IWC) and, 2) the IC₂₅, which represents an estimate of the effluent concentration at which 25% of the test organisms demonstrate inhibition as reflected by lethality, is at any effluent concentration less than or equal to the IWC. The IWC for this permit has been determined to be 21.5% at Outfall 001A and 100% at Outfall 002A. The permittee must provide written notification of the failure of a WET test to the Division, along with a statement as to whether a Preliminary Toxicity Investigation (PTI)/Toxicity Identification Evaluation (TIE) or accelerated testing is being performed (see Part I.A.3.d.). **Notification must be received by the Division within 21 calendar days of the demonstration of chronic WET in the routine required test.** Demonstration for the purposes of Parts I.A.3.b., c., d. and f. means no later than the last day of the laboratory test.

c. Other WET Testing Requirements Applicable to both Chronic and Acute WET Testing

1. Automatic Compliance Schedule Upon Failure of Test

If a routine chronic WET test is failed, regardless of whether the limit is in effect, the following automatic compliance schedule shall apply. As part of this, the permittee shall either:

- i. Proceed to conduct the PTI/TIE investigation as described in Part I.A.3.d., or
- ii. Conduct accelerated testing using the single species found to be more sensitive.

If accelerated testing is being performed, the permittee shall provide written notification of the results within 14 calendar days of completion of the Pattern of Toxicity/No Toxicity demonstration. Testing will be at least once every two weeks for up to five tests until; 1) two consecutive tests fail or three of five tests fail, in which case a pattern of toxicity has been demonstrated or 2) two consecutive tests pass or three of five tests pass, in which case no pattern of toxicity has been found. If no pattern of toxicity is found the toxicity episode is considered to be ended and routine testing is to resume. If a pattern of toxicity is found, a PTI/TIE investigation is to be performed. If a pattern of toxicity is not demonstrated but a significant level of erratic toxicity is found, the Division may require an increased frequency of routine monitoring or some other modified approach.

2. PTI/TIE

The results of the PTI/TIE investigation are to be received by the Division within 120 days of the demonstration of

chronic WET in the routine test, as defined above, or if accelerated testing is performed, the date the pattern of toxicity is demonstrated. A status report is to be provided to the Division at the 30, 60 and 90 day points of the PTI/TIE investigation. The Division may extend the time frame for investigation where reasonable justification exists. A request for an extension must be made in writing and received prior to the 120 day deadline. Such request must include a justification and supporting data for such an extension.

The permittee may use the time for investigation to conduct a PTI or move directly into the TIE. A PTI consists of a brief search for possible sources of WET, which might reveal causes of such toxicity and appropriate corrective actions more simply and cost effectively than a formal TIE. If the PTI allows resolution of the WET incident, the TIE need not necessarily be conducted. If, however, WET is not identified or resolved during the PTI, the TIE must be conducted within the allowed 120 day time frame.

Any permittee that is required to conduct a PTI/TIE investigation shall do so in conformance with procedures identified in the following documents, or as subsequently updated: 1) Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I, EPA/600/6-91/005F May 92, 2) Methods for Aquatic Toxicity Identification Evaluations, Phase I Toxicity Characterization Procedures, EPA/600/6-91/003 Feb. 91 and 3) Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures, EPA/600/3-88/035 Feb. 1989.

A fourth document in this series is Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures, EPA/600/3-88/036 Feb. 1989. As indicated by the title, this procedure is intended to confirm that the suspected toxicant is truly the toxicant. This investigation is optional.

Within 90 days of the determination of the toxicant or no later than 210 days after demonstration of toxicity, whichever is sooner, a control program is to be developed and received by the Division. The program shall set down a method and procedure for elimination of the toxicity to acceptable levels.

3. Request For Relief

The permittee may request relief from further investigation and testing where the toxicant has not been determined and suitable treatment does not appear possible. In requesting such relief, the permittee shall submit material sufficient to establish the following:

- i. It has complied with terms and conditions of the permit compliance schedule for the PTI/TIE investigation and other appropriate conditions as may have been required by the WQCD;
- ii. During the period of the toxicity incident it has been in compliance with all other permit conditions, including, in the case of a POTW, pretreatment requirements;
- iii. During the period of the toxicity incident it has properly maintained and operated all facilities and systems of treatment and control; and
- iv. Despite the circumstances described in paragraphs (i) and (iii) above, the source and/or cause of toxicity could not be located or resolved.

If deemed appropriate by the Division, the permit or the compliance schedule may be modified to revise the ongoing monitoring and toxicity investigation requirements to avoid an unproductive expenditure of the permittee's resources, provided that the underlying obligation to eliminate any continuing exceedance of the toxicity limit shall remain.

4. Spontaneous Disappearance

If toxicity spontaneously disappears at any time after a test failure, the permittee shall notify the Division in writing within 14 days of a demonstration of disappearance of the toxicity. The Division may require the permittee to develop and submit additional information, which may include, but is not limited to, the results of additional testing. If no pattern of toxicity is identified or recurring toxicity is not identified, the toxicity incident response is considered closed and normal WET testing shall resume.

5. Toxicity Reopener

This permit may be reopened and modified (following proper administrative procedures) to include new compliance dates, additional or modified numerical permit limitations, a new or different compliance schedule, a

change in the whole effluent toxicity testing protocol, or any other conditions related to the control of toxicants if one or more of the following events occur:

- i. Toxicity has been demonstrated in the effluent and the permit does not contain a toxicity limitation.
- ii. The PTI/TIE results indicate that the identified toxicant(s) represent pollutant(s) that may be controlled with specific numerical limits and the permit issuing authority agrees that the control of such toxicants through numerical limits is the most appropriate course of action.
- iii. The PTI/TIE reveals other unique conditions or characteristics, which, in the opinion of the permit issuing authority, justify the incorporation of unanticipated special conditions in the permit.

C. DEFINITIONS OF TERMS

1. "Acute Toxicity" means there shall be no acute toxicity in the effluent from this discharge point. The acute toxicity limitation is exceeded if 1) a statistically significant difference in mortality (at the 95% confidence level) is observed for either species between the control and any dilution less than or equal to the identified IWC or 2) a species mortality in any dilution of effluent (including 100% effluent) exceeds 50%. OR "Chronic lethality" occurs when a statistically significant difference, at the 95% confidence level, occurs in the chronic test between the mortality of the test species in «IWC»% effluent (the chronic IWC = «IWC»%) and the control.
2. Antidegradation limits apply as the average of all data collected for months in that group during a rolling 24-month period. These limits become effective after data has been collected for all months in the group during the 24 months following permit issuance. Where antidegradation groups are not indicated, data from all months will be utilized to determine the reported value and the limit will become effective in the 24th month in which the permit is effective.
3. "Continuous" measurement, is a measurement obtained from an automatic recording device which continually measures provides measurements.
4. "Chronic lethality" occurs when a statistically significant difference, at the 95% confidence level, occurs in the chronic test between the mortality of the test species in 100% effluent (the chronic IWC = 100%) and the control.
5. "Daily Maximum limitation" means the limitation for this parameter shall be applied as an instantaneous maximum (or, for pH or DO, instantaneous minimum) value. The instantaneous value is defined as the analytical result of any individual sample. DMR's shall include the maximum (and/or minimum) of all instantaneous values within the calendar month. Any instantaneous value beyond the noted daily maximum limitation for the indicated parameter shall be considered a violation of this permit.
6. "Dissolved (D) metals fraction" is defined in the Basic Standards and Methodologies for Surface Water 1002-31, as that portion of a water and suspended sediment sample which passed through a 0.40 or 0.45 UM (micron) membrane filter. Determinations of "dissolved" constituents are made using the filtrate. This may include some very small (colloidal) suspended particles which passed through the membrane filter as well as the amount of substance present in true chemical solution.
7. "Grab" sample, is a single "dip and take" sample so as to be representative of the parameter being monitored.
8. "In-situ" measurement is defined as a single reading, observation or measurement taken in the field at the point of discharge.
9. "Instantaneous" measurement is a single reading, observation, or measurement performed on site using existing monitoring facilities.
10. "Potentially dissolved (PD) metals fraction" is defined in the Basic Standards and Methodologies for Surface Water 1002-31, as that portion of a constituent measured from the filtrate of a water and suspended sediment sample that was first treated with nitric acid to a pH of 2 or less and let stand for 8 to 96 hours prior to sample filtration using a 0.40 or 0.45-UM (micron) membrane filter. Note the "potentially dissolved" method cannot be used where nitric acid will interfere with the analytical procedure used for the constituent measured.
11. "Quarterly measurement frequency" means samples may be collected at any time during the calendar quarter if a continual discharge occurs. If the discharge is intermittent, then samples shall be collected during the period that discharge occurs.
12. "Recorder" requires the continuous operation of a chart and/or totalizer (or drinking water rotor meters or pump hour meters where previously approved.)
13. "Settleable solids analytical procedure" is contained in 40 CFR 434.64. The method detection limit for measuring

settleable solids under this part shall be 0.4 ml/l.

14. "Seven (7) day average" means, with the exception of fecal coliform or E. coli bacteria, the arithmetic mean of all samples collected in a seven (7) consecutive day period. For fecal coliform or E. coli bacteria, it is the geometric mean of all samples taken in a seven (7) consecutive day period. Such seven (7) day averages shall be calculated for all calendar weeks, which are defined as beginning on Sunday and ending on Saturday. If the calendar week overlaps two months (i.e. the Sunday is in one month and the Saturday in the following month), the seven (7) day average calculated for that calendar week shall be associated with the month that contains the Saturday. Samples may not be used for more than one (1) reporting period. (Not applicable to fecal coliform or E. coli determinations.)
15. "Thirty (30) day average" means the arithmetic mean of all samples collected during a thirty-consecutive-day period. The permittee shall report the appropriate mean of all self-monitoring sample data collected during the calendar month on the Discharge Monitoring Reports. Samples shall not be used for more than one reporting period.
16. "Total Metals" means the concentration of metals determined in an unfiltered sample following vigorous digestion (Section 4.1.3), or the sum of the concentrations of metals in both the dissolved and suspended fractions, as described in Manual of Methods for Chemical Analysis of Water and Wastes, U.S. Environmental Protection Agency, March 1979, or its equivalent
17. "Total Recoverable Metals" means that portion of a water and suspended sediment sample measured by the total recoverable analytical procedure described in Methods for Chemical Analysis of Water and Wastes, U.S. Environmental Protection Agency, March 1979 or its equivalent.
18. "Twice Monthly" monitoring frequency means that two samples shall be collected each calendar month on separate weeks with at least one full week between the two sample dates. Also, there shall be at least one full week between the second sample of a month and the first sample of the following month.
19. "Visual" observation is observing the discharge to check for the presence of a visible sheen or floating oil.
20. "Water Quality Control Division" or "Division" means the state Water Quality Control Division as established in 25-8-101 et al.

Additional relevant definitions are found in the Colorado Water Quality Control Act, CRS §§ 25-8-101 et seq., the Colorado Discharge Permit System Regulations, (Regulation 61 - 5 CCR 1002-61) and other applicable regulations.

D. GENERAL MONITORING, SAMPLING, AND REPORTING REQUIREMENTS

1. Routine Reporting of Data

Reporting of the data gathered in compliance with Part I.B.3. shall be on a quarterly basis. Reporting of all data gathered shall comply with the requirements of Part I.D. (General Requirements). Monitoring results shall be summarized for each calendar quarter and reported on Division approved discharge monitoring report (DMR) forms (EPA form 3320-1). The form shall be mailed to the Division at the address listed below so they are received no later than the 28th day of the month following the end of the quarter (for example, the DMR for the first calendar quarter must be received by the Division by April 28th). If no discharge occurs during the reporting period, "No Discharge" shall be reported.

The DMR forms consist of four pages - the top "original" copy, and three attached no-carbon-required copies. After the DMR form has been filled out and signed, the four copies must be separated and distributed as follows:

The first original signed copy of each discharge monitoring report (DMR) shall be submitted to the Division at the following address:

Colorado Department of Public Health and Environment
Water Quality Control Division
WQCD-P-B2
4300 Cherry Creek Drive South
Denver, CO 80222-1530

Additional copies are for the permittee records. The Discharge Monitoring Report forms shall be filled out accurately and completely in accordance with requirements of this permit and the instructions on the forms. They shall be signed by an authorized person as identified in Part I.D.7 shall sign them.

Calculations for all limitations, which require the averaging of measurements, shall utilize an arithmetic mean unless

otherwise specified by the Division in the permit.

2. Reporting - Stormwater Annual Report

The permittee will be required to submit an Annual Report, covering January 1 through December 31 of each year, on the overall compliance with the SWMP. The Annual Report will contain, at a minimum:

- a) Name of permittee, address, phone number, and permit certification number.
- b) A report on the facility's overall compliance with the SWMP.
- c) A summary of each comprehensive stormwater facility inspection made, including date, findings, and action taken.
- d) Results and interpretation of any stormwater monitoring performed.
- e) The report shall be signed and certified for accuracy by the permittee, including the certification language contained in Part I.D.7. of the permit.

The Annual Report will be due to the Division on or before February 15 of each year, after the first full year of coverage under the permit. The exact due date for the permittee's first Annual Report will be listed in their permit certification. The Division reserves the right to require additional information in the report, on a case-by-case basis, as needed.

All reports required for submittal shall be signed and certified for accuracy by the permittee (see Part I.D.7.).

Colorado Department of Public Health and Environment
Water Quality Control Division
WQCD-P-B2
4300 Cherry Creek Drive South
Denver, CO 80222-1530

3. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other wastestream, body of water, or substance. Monitoring points shall not be changed without notification to and approval by the Division.

If the permittee monitors at the point of discharge any pollutant limited by the permit more frequently than required by the permit, using approved test procedures or as specified in the permit, the result of this monitoring shall be included in the calculation and reporting of data to the Division.

4. Analytical and Sampling Methods for Monitoring

The permittee shall install, calibrate, use and maintain monitoring methods and equipment, including biological and indicated pollutant monitoring methods. All sampling shall be performed by the permittee according to specified methods in 40 C.F.R. Part 136; methods approved by EPA pursuant to 40 C.F.R. Part 136; or methods approved by the Division, in the absence of a method specified in or approved pursuant to 40 C.F.R. part 136. The analytical method selected for a parameter shall be the one that can measure the lowest detected limit for that parameter unless the permit limitation or stream standard for those parameters not limited, is within the testing range of another approved method. When requested in writing, the Division may approve an alternative analytical procedure or any significant modification to an approved procedure.

When the most sensitive analytical method which complies with this part, has a detection limit greater than or equal to the permit limit, the permittee shall report "less than (the detectable limit)," as appropriate. Such reports shall not be considered as violations of the permit limit. The present lowest practical quantitation limits (PQL) for specific parameters (which have limitations that are, in some cases, less than or equal to the detection limit) are as follows:

Effluent Parameter	PQLs, µg/l
Arsenic	1
Cadmium	0.06
Chromium	2
Chromium, Hexavalent	2
Copper	5
Cyanide	10
Iron	10
Lead	1
Manganese	2

Mercury	0.003
Nickel	3
Phenols	15
Selenium	1
Silver	0.5
Uranium	1
Zinc	10

These limits apply to the total recoverable or the potentially dissolved fraction of metals.

For hexavalent chromium, samples must be unacidified so dissolved concentrations will be measured rather than potentially dissolved concentrations. The procedure for determining settleable solids is contained in 40 CFR 434.64. The method detection limit for measuring settleable solids under this part shall be 0.4 ml/l.

5. Records

The permittee shall establish and maintain records. Those records shall include the following:

- a. The date, type, exact location, and time of sampling or measurements;
- b. The individual(s) who performed the sampling or measurements;
- c. The date(s) the analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used;
- f. The results of such analyses; and
- g. Any other observations, which may result in, an impact on the quality or quantity of the discharge as indicated in 40 CFR 122.44 (I)(1)(iii).

The permittee shall retain for a minimum of three (3) years records of all monitoring information, including all original strip chart recordings for continuous monitoring instrumentation, all calibration and maintenance records, copies of all reports required by this permit and records of all data used to complete the application for this permit. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the permittee or when requested by the Division or EPA.

6. Flow Measuring Device

If not already a part of the permitted facility, within ninety (90) days after the effective date of the permit, a flow measuring device shall be installed to give representative values of effluent quantities at the respective discharge points. Unless specifically exempted or modified by the Division, a flow-measuring device will be applicable at all designated discharge points.

At the request of the Division, the permittee shall show proof of the accuracy of any flow-measuring device used in obtaining data submitted in the monitoring report. The flow-measuring device must indicate values within ten (10) percent of the actual flow being discharged from the facility.

7. Signatory and Certification Requirements

- a. All reports and other information required by the Division, shall be signed and certified for accuracy by the permittee in accord with the following criteria:
 - i) In the case of corporations, by a principal executive officer of at least the level of vice-president or his or her duly authorized representative, if such representative is responsible for the overall operation of the facility from which the discharge described in the form originates;
 - ii) In the case of a partnership, by a general partner;
 - iii) In the case of a sole proprietorship, by the proprietor;
 - iv) In the case of a municipal, state, or other public facility, by either a principal executive officer, ranking elected official, or other duly authorized employee.
- b. All reports required by permits, and other information requested by the Division shall be signed by a person as described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- i) The authorization is made in writing by a person described above;
- ii) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and,
- iii) The written authorization is submitted to the Division.

If an authorization as described in this section is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of this section must be submitted to the Division prior to or together with any reports, information, or applications to be signed by an authorized representative.

The permittee, or the duly authorized representative shall make and sign the following certification on all such documents:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

PART II

A. NOTIFICATION REQUIREMENTS

1. Notification to Parties

All notification requirements under this section shall be directed as follows:

a. **Oral Notifications, other than for spills, during normal business hours** shall be to:

Water Quality Protection Section - Industrial Compliance Program
Water Quality Control Division
Telephone: (303) 692-3500

Spills notifications at any time and other notifications after hours shall be to:

Emergency Management Program
Laboratory and Radiation Services Division
Telephone: (877) 518-5608

b. **Written notification** shall be to:

Water Quality Protection Section - Industrial Compliance Program
Water Quality Control Division
Colorado Department of Public Health and Environment
WQCD-WQP-B2
4300 Cherry Creek Drive South
Denver, CO 80246-1530

2. Change in Discharge

Notice is required only when:

- a. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged, or;
- b. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported pursuant to an approved land application plan.

The permittee shall give advance notice to the Division of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

Whenever notification of any planned physical alterations or additions to the permitted facility is required pursuant to this section, the permittee shall furnish the Division such plans and specifications which the Division deems reasonably necessary to evaluate the effect on the discharge, the stream, or ground water. If the Division finds that such new or altered discharge might be inconsistent with the conditions of the permit, the Division shall require a new or revised permit application and shall follow the procedures specified in Sections 61.5 through 61.6, and 61.15 of the Colorado Discharge Permit System Regulations.

3. Special Notifications - Definitions

- a. **Bypass:** The intentional diversion of waste streams from any portion of a treatment facility.
- b. **Severe Property Damage:** Substantial physical damage to property at the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. It does not mean economic loss caused by delays in production.
- c. **Spill:** An incident in which flows or solid materials are accidentally or unintentionally allowed to flow or escape so as

to be lost from the treatment, processing or manufacturing system which may cause or threaten pollution of state waters.

- d. Upset: An exceptional incident in which there is unintentional and temporary noncompliance with permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventative maintenance, or careless or improper operation.

4. Noncompliance Notification

- a. If, for any reason, the permittee does not comply with or will be unable to comply with any discharge limitations or standards specified in this permit, the permittee shall, at a minimum, provide the Division and EPA with the following information:
 - i) A description of the discharge and cause of noncompliance;
 - ii) The period of noncompliance, including exact dates and times and/or the anticipated time when the discharge will return to compliance; and
 - iii) Steps being taken to reduce, eliminate, and prevent recurrence of the noncomplying discharge.
- b. The permittee shall report the following circumstances **orally within twenty-four (24) hours** from the time the permittee becomes aware of the circumstances, and shall mail to the Division a written report containing the information requested in Part II.A.4 (a) **within five (5) days** after becoming aware of the following circumstances:
 - i) Circumstances leading to any noncompliance which may endanger health or the environment regardless of the cause of the incident;
 - ii) Circumstances leading to any unanticipated bypass which exceeds any effluent limitations in the permit;
 - iii) Circumstances leading to any upset or spill which causes an exceedance of any effluent limitation in the permit;
 - iv) Daily maximum violations for any of the pollutants limited by Part I.A of this permit and specified as requiring 24-hour notification. This includes any toxic pollutant or hazardous substance or any pollutant specifically identified as the method to control any toxic pollutant or hazardous substance.
- c. The permittee shall report instances of non-compliance which are not required to be reported within 24-hours at the time Discharge Monitoring Reports are submitted. The reports shall contain the information listed in sub-paragraph (a) of this section.

5. Other Notification Requirements

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule in the permit shall be submitted no later than fourteen (14) days following each scheduled date, unless otherwise provided by the Division.

The permittee shall notify the Division, in writing, thirty (30) days in advance of a proposed transfer of permit as provided in Part II.B.3.

The permittee's notification of all anticipated noncompliance does not stay any permit condition.

All existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Division as soon as they know or have reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. One hundred micrograms per liter (100 ug/l);
 - ii. Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;

iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with Section 61.4(2)(g).

iv. The level established by the Division in accordance with 40 CFR ' 122.44(f).

b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":

i. Five hundred micrograms per liter (500 ug/l);

ii. One milligram per liter (1 mg/l) for antimony; and

iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application.

iv. The level established by the Division in accordance with 40 CFR ' 122.44(f).

6. Bypass Notification

If the permittee knows in advance of the need for a bypass, a notice shall be submitted, at least ten days before the date of the bypass, to the Division. The bypass shall be subject to Division approval and limitations imposed by the Division. Violations of requirements imposed by the Division will constitute a violation of this permit.

7. Upsets

a. Effect of an Upset.

An upset constitutes an affirmative defense to an action brought for noncompliance with permit effluent limitations if the requirements of paragraph (b) of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

b. Conditions Necessary for a Demonstration of Upset

A permittee who wishes to establish the affirmative defense of upset shall demonstrate through properly signed contemporaneous operating logs, or other relevant evidence that:

i. An upset occurred and that the permittee can identify the specific cause(s) of the upset; and

ii. The permitted facility was at the time being properly operated and maintained; and

iii. The permittee submitted proper notice of the upset as required in Part II.A.4. of this permit (24-hour notice); and

iv. The permittee complied with any remedial measure necessary to minimize or prevent any discharge or sludge use or disposal in violation of this permit, which has a reasonable likelihood of adversely affecting human health or the environment.

In addition to the demonstration required above, a permittee who wishes to establish the affirmative defense of upset for a violation of effluent limitations based upon water quality standards shall also demonstrate through monitoring, modeling or other methods that the relevant standards were achieved in the receiving water.

c. Burden of Proof

In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

8. Discharge Point

Any discharge to the waters of the State from a point source other than specifically authorized by this permit is prohibited.

9. Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and

related appurtenances) which are installed or used by the permittee as necessary to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by the permittee only when necessary to achieve compliance with the conditions of the permit.

10. Minimization of Adverse Impact

The permittee shall take all reasonable steps to minimize or prevent any discharge of sludge use or disposal in violation of this permit, which has a reasonable likelihood of adversely affecting human health or the environment. As necessary, accelerated or additional monitoring to determine the nature and impact of the noncomplying discharge is required.

11. Removed Substances

Solids, sludges, or other pollutants removed in the course of treatment or control of wastewaters shall be disposed in accordance with applicable state and federal regulations. For all domestic wastewater treatment works, at industrial facilities, the permittee shall dispose of sludge in accordance with all State and Federal regulations.

12. Submission of Incorrect or Incomplete Information

Where the permittee failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or report to the Division, the permittee shall promptly submit the relevant information, which was not submitted, or any additional information needed to correct any erroneous information previously submitted

13. Bypass

- a. Bypasses are prohibited and the Division may take enforcement action against the permittee for bypass, unless:
 - i. The bypass is unavoidable to prevent loss of life, personal injury, or severe property damage;
 - ii. There were no feasible alternatives to bypass such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - iii. Proper notices were submitted in compliance with Part II.A.4.
- b. "Severe property damage" as used in this Subsection means substantial physical damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources, which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- c. The permittee may allow a bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance or to assure optimal operation. These bypasses are not subject to the provisions of paragraph a. above.
- d. The Division may approve an anticipated bypass, after considering adverse effects, if the Division determines that the bypass will meet the conditions specified in paragraph a. above.

14. Reduction, Loss, or Failure of Treatment Facility

The permittee has the duty to halt or reduce any activity if necessary to maintain compliance with the effluent limitations of the permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production, control sources of wastewater, or all discharges, until the facility is restored or an alternative method of treatment is provided. This provision also applies to power failures, unless an alternative power source sufficient to operate the wastewater control facilities is provided.

It shall not be a defense for a permittee in an enforcement action that it would be necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

B. RESPONSIBILITIES

1. Inspections and Right to Entry

The permittee shall allow the Division and/or the authorized representative, upon the presentation of credentials:

- a. To enter upon the permittee's premises where a regulated facility or activity is located or in which any records are required to be kept under the terms and conditions of this permit;
- b. At reasonable times to have access to and copy any records required to be kept under the terms and conditions of this permit and to inspect any monitoring equipment or monitoring method required in the permit; and
- c. To enter upon the permittee's premises in a reasonable manner and at a reasonable time to inspect and/or investigate, any actual, suspected, or potential source of water pollution, or to ascertain compliance or non compliance with the Colorado Water Quality Control Act or any other applicable state or federal statute or regulation or any order promulgated by the Division. The investigation may include, but is not limited to, the following: sampling of any discharge and/or process waters, the taking of photographs, interviewing of any person having knowledge related to the discharge permit or alleged violation, access to any and all facilities or areas within the permittee's premises that may have any affect on the discharge, permit, or alleged violation. Such entry is also authorized for inspecting and copying records required to be kept concerning any effluent source.
- d. The permittee shall provide access to the Division to sample the discharge at a point after the final treatment process but before the discharge mixing with state waters upon presentation of proper credentials.

In the making of such inspections, investigations, and determinations, the Division, insofar as practicable, may designate as its authorized representatives any qualified personnel of the Department of Agriculture. The Division may also request assistance from any other state or local agency or institution.

2. Duty to Provide Information

The permittee shall furnish to the Division, within a reasonable time, any information which the Division may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Division, upon request, copies of records required to be kept by this permit.

3. Transfer of Ownership or Control

- a. Except as provided in paragraph b. of this section, a permit may be transferred by a permittee only if the permit has been modified or revoked and reissued as provided in Section 61.8(8) of the Colorado Discharge Permit System Regulations, to identify the new permittee and to incorporate such other requirements as may be necessary under the Federal Act .
- b. A permit may be automatically transferred to a new permittee if:
 - i. The current permittee notifies the Division in writing 30 days in advance of the proposed transfer date; and
 - ii. The notice includes a written agreement between the existing and new permittee(s) containing a specific date for transfer of permit responsibility, coverage and liability between them; and
 - iii. The Division does not notify the existing permittee and the proposed new permittee of its intent to modify, or revoke and reissue the permit.
 - iv. Fee requirements of the Regulations for the State Discharge Permit System, Section 61.15 have been met.

4. Availability of Reports

Except for data determined to be confidential under Section 308 of the Federal Clean Water Act and Colorado Discharge Permit System Regulations 5 CCR 1002-61, Section 61.5.(4), all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Division and the Environmental Protection Agency.

The name and address of the permit applicant(s) and permittee(s), permit applications, permits and effluent data shall not be considered confidential. Knowingly making false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the Federal Clean Water Act, and Section 25-8-610 C.R.S.

5. Modification, Suspension, Revocation, or Termination of Permits By the Division

The filing of a request by the permittee for a permit modification, revocation, and reissuance/termination or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

- a. A permit may be modified, suspended, or terminated in whole or in part during its term for reasons determined by the Division including, but not limited to, the following:
 - i. Violation of any terms or conditions of the permit;
 - ii. Obtaining a permit by misrepresentation or failing to disclose any fact which is material to the granting or denial of a permit or to the establishment of terms or conditions of the permit; or
 - iii. Materially false or inaccurate statements or information in the permit application or the permit.
 - iv. A determination that the permitted activity endangers human health or the classified or existing uses of state waters and can only be regulated to acceptable levels by permit modifications or termination.
- b. A permit may be modified in whole or in part for the following causes, if such modification complies with the provisions of Section 61.10 of the Colorado Discharge Permit System Regulations:
 - i. There are material and substantial alterations or additions to the permitted facility or activity which occurred after permit issuance which justify the application of permit conditions that are different or absent in the existing permit.
 - ii. The Division has received new information which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of different permit conditions at the time of issuance. For permits issued to new sources or new dischargers, this cause includes information derived from effluent testing required under Section 61.4(7)(e) of the Colorado Discharge Permit System Regulations. This provision allows a modification of the permit to include conditions that are less stringent than the existing permit only to the extent allowed under Section 61.10 of the Colorado Discharge Permit System Regulations.
 - iii. The standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued. Permits may be modified during their terms for this cause only as follows:
 - (A) The permit condition requested to be modified was based on a promulgated effluent limitation guideline, EPA approved water quality standard, or an effluent limitation set forth in 5 CCR 1002-62, '62 et seq.; and
 - (B) EPA has revised, withdrawn, or modified that portion of the regulation or effluent limitation guideline on which the permit condition was based, or has approved a Commission action with respect to the water quality standard or effluent limitation on which the permit condition was based; and
 - (C) The permittee requests modification after the notice of final action by which the EPA effluent limitation guideline, water quality standard, or effluent limitation is revised, withdrawn, or modified; or
 - (D) For judicial decisions, a court of competent jurisdiction has remanded and stayed EPA promulgated regulations or effluent limitation guidelines, if the remand and stay concern that portion of the regulations or guidelines on which the permit condition was based and a request is filed by the permittee in accordance with this Regulation, within ninety (90) days of judicial remand.
 - iv. The Division determines that good cause exists to modify a permit condition because of events over which the permittee has no control and for which there is no reasonable available remedy.
 - v. The permittee has received a variance.
 - vi. When required to incorporate applicable toxic effluent limitation or standards adopted pursuant to '307(a) of the Federal act.
 - vii. When required by the reopener conditions in the permit.
 - viii. As necessary under 40 C.F.R. 403.8(e), to include a compliance schedule for the development of a pretreatment program.
 - ix. When the level of discharge of any pollutant, which is not limited in the permit, exceeds the level, which can be achieved by the technology-based treatment requirements appropriate to the permittee under Section 61.8(2) of the Colorado Discharge Permit System Regulations.
 - x. To establish a pollutant notification level required in Section 61.8(5) of the Colorado Discharge Permit System Regulations.

- xi. To correct technical mistakes, such as errors in calculation, or mistaken interpretations of law made in determining permit conditions, to the extent allowed in Section 61.10 of the Colorado Discharge Permit System Regulations.
 - xii. When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge, to revise an existing land application plan, or to add a land application plan.
 - xiii. For any other cause provided in Section 61.10 of the Colorado Discharge Permit System Regulations.
- c. At the request of a permittee, the Division may modify or terminate a permit and issue a new permit if the following conditions are met:
- i. The Regional Administrator has been notified of the proposed modification or termination and does not object in writing within thirty (30) days of receipt of notification,
 - ii. The Division finds that the permittee has shown reasonable grounds consistent with the Federal and State statutes and regulations for such modifications or termination;
 - iii. Requirements of Section 61.15 of the Colorado Discharge Permit System Regulations have been met, and
 - iv. Requirements of public notice have been met.
- d. Permit modification (except for minor modifications), termination or revocation and reissuance actions shall be subject to the requirements of Sections 61.5(2), 61.5(3), 61.6, 61.7 and 61.15 of the Colorado Discharge Permit System Regulations. The Division shall act on a permit modification request, other than minor modifications requests, within 180 days of receipt thereof. Except for minor modifications, the terms of the existing permit govern and are enforceable until the newly issued permit is formally modified or revoked and reissued following public notice.
- e. Upon consent by the permittee, the Division may make minor permit modifications without following the requirements of Sections 61.5(2), 61.5(3), 61.7, and 61.15 of the Colorado Discharge Permit System Regulations. Minor modifications to permits are limited to:
- i. Correcting typographical errors; or
 - ii. Increasing the frequency of monitoring or reporting by the permittee; or
 - iii. Changing an interim date in a schedule of compliance, provided the new date of compliance is not more than 120 days after the date specific in the existing permit and does not interfere with attainment of the final compliance date requirement; or
 - iv. Allowing for a transfer in ownership or operational control of a facility where the Division determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittees has been submitted to the Division; or
 - v. Changing the construction schedule for a discharger which is a new source, but no such change shall affect a discharger's obligation to have all pollution control equipment installed and in operation prior to discharge; or
 - vi. Deleting a point source outfall when the discharge from that outfall is terminated and does not result in discharge of pollutants from other outfalls except in accordance with permit limits.
- f. When a permit is modified, only the conditions subject to modification are reopened. If a permit is revoked and reissued, the entire permit is reopened and subject to revision and the permit is reissued for a new term.
- g. The filing of a request by the permittee for a permit modification, revocation and reissuance or termination does not stay any permit condition.
- h. All permit modifications and reissuances are subject to the antibacksliding provisions set forth in 61.10 (e) through (g).
6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 (Oil and Hazardous Substance Liability) of the Clean Water Act.

7. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority

granted by Section 510 of the Clean Water Act.

8. Permit Violations

Failure to comply with any terms and/or conditions of this permit shall be a violation of this permit. The discharge of any pollutant identified in this permit more frequently than or at a level in excess of that authorized shall constitute a violation of the permit.

9. Property Rights

The issuance of this permit does not convey any property or water rights in either real or personal property, or stream flows, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

10. Severability

The provisions of this permit are severable. If any provisions of this permit, or the application of any provision of this permit to any circumstance, are held invalid, the application of such provision to other circumstances and the application of the remainder of this permit shall not be affected.

11. Renewal Application

If the permittee desires to continue to discharge, a permit renewal application shall be submitted at least one hundred eighty (180) days before this permit expires. If the permittee anticipates there will be no discharge after the expiration date of this permit, the Division should be promptly notified so that it can terminate the permit in accordance with Part II.B.5.

12. Confidentiality

Any information relating to any secret process, method of manufacture or production, or sales or marketing data which has been declared confidential by the permittee, and which may be acquired, ascertained, or discovered, whether in any sampling investigation, emergency investigation, or otherwise, shall not be publicly disclosed by any member, officer, or employee of the Commission or the Division, but shall be kept confidential. Any person seeking to invoke the protection of this Subsection (12) shall bear the burden of proving its applicability. This section shall never be interpreted as preventing full disclosure of effluent data.

13. Fees

The permittee is required to submit payment of an annual fee as set forth in the 1983 amendments to the Water Quality Control Act. Section 25-8-502 (l) (b), and the Colorado Discharge Permit System Regulations 5 CCR 1002-61, Section 61.15 as amended. Failure to submit the required fee when due and payable is a violation of the permit and will result in enforcement action pursuant to Section 25-8-601 et. seq., C.R.S. 1973 as amended.

14. Duration of Permit

The duration of a permit shall be for a fixed term and shall not exceed five (5) years. Filing of a timely and complete application shall cause the expired permit to continue in force to the effective date of the new permit. The permit's duration may be extended only through administrative extensions and not through interim modifications.

15. Section 307 Toxics

If a toxic effluent standard or prohibition, including any applicable schedule of compliance specified, is established by regulation pursuant to Section 307 of the Federal Act for a toxic pollutant which is present in the permittee's discharge and such standard or prohibition is more stringent than any limitation upon such pollutant in the discharge permit, the Division shall institute proceedings to modify or revoke and reissue the permit to conform to the toxic effluent standard or prohibition.

16. Antibacksliding

- a. A permit may not be renewed, reissued, or modified to contain effluent limitations adopted pursuant to Section 25-8-503(1)(b) (BPJ) of the Water Quality Control Act, which are less stringent than the comparable effluent limitations or standards in the previous permit, unless any one of the following exceptions is met and the conditions of paragraph c. of this section are met:

- i. Material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of less stringent effluent limitations; or
 - ii. Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation or standard at the time of permit issuance; or
 - iii. The Division determines that technical mistakes or mistaken interpretations of law were made in issuing the permit, which justified relaxation of the effluent limitations or standards; or
 - iv. A less stringent effluent limitation or standard is necessary because of events over which the permittee has no control and for which there is not reasonable available remedy; or
 - v. The permittee has received a permit variance; or
 - vi. The permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit and has properly operated and maintained the facilities but has nevertheless been unable to achieve the previous effluent limitations, in which case, the limitations in the renewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).
- b. A permit may not be renewed, reissued, or modified to contain effluent limitations adopted pursuant to 61.8(2)(b) or (c) of the Colorado Discharge Permit System Regulations that are less stringent than the comparable effluent limitations in the previous permit, unless any of the exceptions provided herein is met and the conditions of paragraph c. of this section are met.
- i. In waters where the applicable water quality standard has not yet been attained, effluent limitations based on a total maximum daily load or other waste load allocation may be revised to be less stringent if the cumulative effect of all such revisions assures attainment of such water quality standard, or the designated use which is not being attained is removed in accordance with Section 31.6 of the Basic Standards.
 - ii. In waters where the applicable water quality standard has been attained, effluent limitations based on a total maximum daily load, other waste load allocation, or any other permitting standard (including any water quality standard) may be revised to be less stringent if such revision is subject to and consistent with the antidegradation provisions of Section 31.8 of the Basic Standards. Consistency with Section 31.8 shall be presumed if the waters in question have been designated by the Commission as "use protected"; or
 - iii. Whether or not the applicable water quality standard has been attained:
 - (A) Material and substantial alterations or additions to the permitted facility occurred after permit issuance which justified the application of less stringent effluent limitations; or
 - (B) A less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is not reasonable available remedy; or
 - (C) The permittee has received a permit variance; or
 - (D) The permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit and has properly operated and maintained the facilities but has nevertheless been unable to achieve the previous effluent limitations, in which case, the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).
- c. In no event may a permit with respect to which paragraphs a. and b. of this section apply be renewed, reissued, or modified to contain an effluent limitation or standard which is less stringent than required by federal effluent guidelines in effect at the time the permit is renewed, reissued, or modified. In no event may such a permit to discharge into state waters be renewed, reissued, or modified to contain a less stringent effluent limitation if the implementation of such limitation would result in a violation of an applicable water quality standard.

17. Effect of Permit Issuance

- a. The issuance of a permit does not convey any property rights or any exclusive privilege.
- b. The issuance of a permit does not authorize any injury to person or property or any invasion of personal rights, nor does it authorize the infringement of federal, state, or local laws or regulations.
- c. Except for any toxic effluent standard or prohibition imposed under Section 307 of the Federal act or any standard for sewage sludge use or disposal under Section 405(d) of the Federal act, compliance with a permit during its term constitutes compliance, for purposes of enforcement, with Sections 301, 302, 306, 318, 403, and 405(a) and (b) of the Federal act. However, a permit may be modified, revoked and reissued, or terminated during its term for cause as set forth in Section 61.8(8) of the Colorado Discharge Permit System Regulations.

- d. Compliance with a permit condition which implements a particular standard for sewage sludge use or disposal shall be an affirmative defense in any enforcement action brought for a violation of that standard for sewage sludge use or disposal.

18. Requiring an Individual CDPS Permit

The Director may require any owner or operator covered under this permit to apply for and obtain an individual CDPS permit if:

- a. The discharger is not in compliance with the conditions of this General Permit; or,
- b. Conditions or standards have changed so that the discharge no longer qualifies for a General Permit; or,
- c. Data becomes available which indicates water quality standards may be violated.

The owner or operator must be notified in writing that an application for an individual CDPS permit is required. When an individual CDPS permit is issued to an owner or operator otherwise covered under this General Permit, the applicability of the General Permit to that owner or operator is automatically terminated upon the effective date of the individual CDPS permit.

19. Requesting an Individual CDPS Permit

Any owner or operator covered by this General Permit may request to be excluded from the coverage by applying for an individual CDPS permit.

20. Requesting Coverage Under the General Permit

The owner or operator of a facility excluded from coverage by this General Permit solely because that facility already has an individual permit may request that the individual permit be revoked and that the facility be covered by this General Permit. Such request shall be evaluated by the Division per criterion specified in Part I of this permit.