Groundwater Entry Point Chlorine Residual Monitoring Log

Revision: 4/1/2016

Do not submit, unless requested by the Department.
Retain for inspections or requests.

GWR EP

PWS ID:	System Name:
Facility ID:	Facility Name:
Contact Person:	Phone # or E-mail:
Sample Month:	Sample Year:

1) In the case where the entry point was not used please record "PO" for Plant Off.

2) For systems <u>not</u> 4-log certified by the Department:

a) **<u>Each</u>** entry point must be measured **<u>once per week,</u>** unless it did not serve water to the distribution system.

b) If a measurement is less than 0.2 mg/L, samples must be collected **<u>every 24 hours</u>** until the entry point residual is measured at or above 0.2 mg/L.

c) If **<u>72 hours pass</u>** without a measurement at or above 0.2 mg/L, the Department must be notified no later than the next business day as a treatment technique violation has occurred and Tier 2 Public Notice must be distributed.

3) For systems 4-log certified by the Department:

a) If a measurement is less than the system specified entry point minimum residual the system has 4 hours to increase the entry point residual.

b) If 4 hours pass without a measurement at or above the system specified minimum then the Department must be notified no later than the next business day as a treatment technique violation has occurred and Tier 2 Public Notice must be distributed.

Date	Time	Result (mg/L)	Comments