



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

May 26, 2016

Kent Beach, Owner
Beach Redi Mix
PO Box 307
Westcliffe, CO 81252

Subject: Beach Redi Mix; Septic Tank - Acceptance
For Use in Colorado On-site Wastewater Treatment Systems

Dear Mr. Beach:

Pursuant to section 43.13 of the On-site Wastewater Treatment System Regulation 5 CCR 1002-43 (Regulation 43), the Water Quality Control Division (Division) has reviewed drawings and specifications received May 19, 2016 for the following tanks:

- Model 1000T and 1000STEP
- Model 1250T and 1250STEP
- Model 1500T and 1500STEP
- All tanks are double compartment

The Division finds the tank design to be consistent with the criteria of section 43.9 of Regulation 43. The Division also provides this acceptance of the tank(s) referenced above as meeting these criteria and acceptable for use in Colorado.

Note: Pursuant to section 43.13(G)(2), at least five percent of tanks must be tested for watertightness at the manufacturing facility. A summary of testing results must be submitted to the Division on an annual basis (by February 15, each calendar year). The testing results submittal form is available on the Division website. If you participate in the Plant Certification Program of the National Precast Concrete Association (NPCA), watertightness testing is not required pursuant to section 43.13(G)(2). However, a copy of your annual certification must be provided to the Division on an annual basis.

This acceptance does not constitute an endorsement of this product. As individual local public health agency regulations may be more stringent than Regulation 43, the Division cannot ensure the acceptance of a septic tank within any given jurisdiction.

If you have any questions regarding the Division's review or findings, please contact me at (303) 692-2366 or chuck.cousino@state.co.us.

Sincerely,

Charles J. Cousino, REHS
On-site Wastewater Treatment System Coordinator
Engineering Section | Water Quality Control Division
Colorado Department of Public Health and Environment

