


NOTES:

1. STOP BOX MUST BE PLACED IN PUBLIC RIGHT-OF-WAY AS CLOSE TO CURB AS POSSIBLE.
2. IF THERE IS A TREE LAWN, BOTH CURB STOP AND METER PIT MUST BE LOCATED BETWEEN CURB AND SIDEWALK.
3. STOP BOX SHALL BE LOCATED IN A LANDSCAPED AREA, 24" FROM THE INLET SIDE OF THE METER PIT UNLESS PRIOR APPROVAL IS OBTAINED FROM METER INSPECTOR. FOR CURB STOP LOCATED BENEATH PAVEMENT, USE ROADWAY BOX OVER STANDARD STOP BOX. CURB STOP CANNOT BE LOCATED BENEATH PARKING AREAS.
4. STOP BOX AND METER PIT MUST BE ACCESSIBLE AT ALL TIMES. DO NOT PLACE FENCE, TREE, WALL OR OTHER OBSTRUCTION WITHIN 5 FT OF STOP BOX OR METER PIT.
5. METER PIT/VAULT SHALL CONFORM WITH DENVER WATER DETAILS ON SHEET 49 OR SHEET 55, AS APPLICABLE.
6. NO BENDS, FITTINGS, CONNECTIONS OR CHANGES IN PIPE SIZE ARE PERMITTED BETWEEN THE TAP AND A POINT 5 FT BEYOND THE WALL OF THE METER PIT. INCREASE OF ONE PIPE SIZE PERMITTED 5 FT AFTER PIT.
7. DENVER WATER WILL REPAIR SERVICE LINE LEAKS BETWEEN THE CORPORATION STOP AND THE OUTLET TO THE CURB STOP ONLY INSIDE DENVER AND IN TOTAL SERVICE DISTRICTS ONLY. PROPERTY OWNER IS RESPONSIBLE FOR ALL OTHER SERVICE LINE REPAIRS OR REPLACEMENT FROM THE CORPORATION STOP ON THE WATER MAIN IN THE STREET.



I:\ACL10300842925\CAD\Details\water service.dwg, Model, 8/4/2010 8:29:33 AM, preefe, 1:1

REVISION DESCRIPTION	
MERRICK PROJECT NO.	0300842920
DRAWN	PAR
2450 S. Peoria St., Aurora, Co. 80014 Phone: 303-751-0741	

BEAR CREEK WATER & SANITATION DISTRICT DOMESTIC WATER SERVICE LINE: STOP BOX & OUTSIDE METER INSTALLATION	
DATE: AUGUST 3, 2010	
SCALE: N/A	SHEET 1 OF 1