



Colorado Department of Labor and Employment
 Division of Oil and Public Safety – Boiler Inspection Program
 633 17th Street, Suite 500
 Denver, CO 80202-3610

Phone: 303-318-8484
 Fax: 303-318-8534
 Email: cdle_boiler@state.co.us
 Web: www.colorado.gov/ops

Installation Application

(revised 6/2015)

Completion of this application is **mandatory** for all newly installed or used boilers and pressure vessels per the [Boiler Inspection Regulations](#). The boiler owner or installer must submit the completed application to the Boiler Inspection Program via email to catherine.johnson@state.co.us or by mailing it to the address listed above. Contact us if you have any questions.

Please allow up to two (2) weeks for the State inspector to schedule an inspection appointment.

Boiler/Pressure Vessel Location Information

Installation Date:		Building Name:			
Street Address:		City:		State:	ZIP:
County:					
Contact Name:		Phone Number:			

Owner/Responsible Party Information

Company Name:					
Mailing Address:		City:		State:	ZIP:
Contact Name:		Phone Number:			
Email Address:					

Installer Information

Company Name:					
Mailing Address:		City:		State:	ZIP:
Contact Name:		Phone Number:			
Email Address:					

Boiler/Pressure Vessel Information

Type of Vessel:		New or Used:	<input type="checkbox"/> New	<input type="checkbox"/> Used
Did this object replace another?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<i>(If yes) Boiler # replaced:</i>	
Manufacturer Name:		Serial #:		
National Board #:		Year Built:		
ASME Code of Construction:		Location in Plant:		
MAWP:		BTU/KW Input:		
Safety Valve Capacity:		Safety Valve Set Pressure:		
<i>Safety Valve Relieving Capacity:</i>		LBS/hr	BTU/hr	CFM

Comments

--

Additional Documentation

Attach a copy of the Manufacturer's Data Report, which should include:

- ASME Forms P-2 or P-3 (for Power Boilers) also P-4a or P-4b for piping and P-7 for Safety Valve, as applicable;
- ASME Forms H-2 or H-3 (for Heating Boilers; cast iron is exempt);
- ASME Forms HLW-6 (for Lined Water Heaters) >200,000 BTU; and
- ASME Forms U-1 or U-1a (for Pressure Vessels).